

FILED

OCT 25 2010



# APPLICATION FOR APPEAL

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

**The City Clerk needs the following to process your appeal:**

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, NOV 2

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1386 Eleanor Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: \_\_\_\_\_

Name of Owner (if other than Appellant): Gail Hesselbeck

Address (if not Appellant's): 1386 Eleanor Ave

Phone Numbers: Business \_\_\_\_\_ Residence 952-769-7824 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 4 replacement windows that will not comply w/ egress. All 4 windows will be short by 2" in operable height. Windows will exceed operable width by 10". Please Approve.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: October 21, 2010

APPEAL PROPERTY ADDRESS: 1386 ELEANOR AVE  
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION  
PHONE NUMBER: 651-266-9071  
PERMIT NUMBER: 10 913106  
TYPE OF WINDOW: Double Hung  
NUMBER OF WINDOWS: 4

Total Glazed Area	12.4 sq. ft.	Difference from Required Area	+ 7.4 sq. ft.
Width of Opening	30"	Difference from Required Opening	+ 10"
Height of Opening	22"	Difference from Required Opening	- 2"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.