

Scanned

Hearing date  
5/10/11 1:30

Saint Paul - Ramsey County Department of Public Health  
Environmental Health Section  
2785 White Bear Avenue North Suite 350  
Maplewood, MN 55109-1320  
FAX: (651) 266-1177

Date: 4-25-11

To FAX#: 6-8574

FACSIMILE TRANSMISSION  
Cover Sheet and Transmittal Form

RECEIVED  
APR 25 2011  
CITY CLERK

To: Mai Yang, Paralegal

Location: Legislative Hearing Office  
City of St. Paul

Sender: Daniel Schmidt / Tim Yannarelli  
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of 4 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form

→ 1097 ORANGE

→ 658 CHARLES

**CONFIDENTIALITY NOTICE**

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 4-25-11

APPEAL PROPERTY ADDRESS: 1097 ORANGE  
APPLICANT NAME: PUBLIC HEALTH (DANIEL) PHONE NUMBER: 651-266-1143  
ON BEHALF OF: TAMMIE NEUMENFELT

PERMIT NUMBER: \_\_\_\_\_

TYPE OF WINDOW: WOOD DOUBLE HUNG

NUMBER OF WINDOWS: 3

TOTAL GLAZED AREA: 7.3 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 22" DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 21 1/2" DIFFERENCE FROM REQUIRED OPENING: 2.5"

HEIGHT OF OPENING  
TO FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

FROM: \_\_\_\_\_