

✓ Scanned



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

No. 1083 P. 5

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 6-6-12

APPEAL PROPERTY ADDRESS: 1083 ARUNDEL ST.

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 9.1 sqft DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: 25.2" DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING: 20.06" DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING TO FINISHED FLOOR: 248" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE):

FROM: _____

Jun. 6. 2012 3:38PM

St Paul-Ramsey Co. Public Health