

Moermond, Marcia (CI-StPaul)

From: Moermond, Marcia (CI-StPaul)
Sent: Wednesday, August 17, 2016 1:39 PM
To: Wiese, Angie (CI-StPaul); bill hosko
Cc: Neis, Adrian (CI-StPaul); Vang, Mai (CI-StPaul)
Subject: RE: Fire Retardant spec sheets for the Cafe

All,

I will recommend that use of Flame Guard be allowed to treat the trees, as an alternative means of compliance. Also, I am recommending that the Council grant 2 months to come in compliance with the orders.

Marcia

From: Wiese, Angie (CI-StPaul)
Sent: Wednesday, August 17, 2016 11:20 AM
To: bill hosko
Cc: Moermond, Marcia (CI-StPaul); Neis, Adrian (CI-StPaul)
Subject: RE: Fire Retardant spec sheets for the Cafe

Bill,

The Lumber Guard is *not* an appropriate application for the trees you have.

The Flame Guard is an appropriate application for your trees. We will accept FX Flame Guard as applied per the manufacturer's instructions.

I am not sure if Marcia gave you a time to comply. I will leave that between you and her.



Angie Wiese, PE, CBO
Fire Protection Engineer

Safety & Inspections
375 Jackson St. Suite 220
Saint Paul, MN 55101
P: 651-266-8953
F: 651-266-8951
angie.wiese@ci.stpaul.mn.us

The Most Livable
City in America

Fire is Everyone's Fight

DSI's Mission: To preserve and improve the quality of life in Saint Paul by protecting and promoting public health and safety for all.

From: bill hosko [<mailto:billhosko@yahoo.com>]
Sent: Wednesday, August 17, 2016 9:48 AM
To: Wiese, Angie (CI-StPaul) <angie.wiese@ci.stpaul.mn.us>
Subject: Fw: Fire Retardant spec sheets for the Cafe

Hello Angie,

Please let me know if you need further information. If all is good I would still like to wait to apply the material until after Christmas, early January, only 5 months away now. ;-)

Thank you.

Bill

On Friday, August 12, 2016 1:50 PM, Doug Stafford <doug@rdrtechnologies.com> wrote:

Bill - attaching two spec sheets for possible retardants. I'm recommending the Lumber Guard. It has the most test data, it will soak into the wood, and won't change the look and feel of the trees.

--

Doug Stafford
RDR Technologies
405-306-3062 c
405-702-0055 o
doug@rdrtechnologies.com