



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

April 29, 2011

Russell Senn
1916 Timberwolf Trail N
Eagan MN 55122

Re: Appeal for property at 231 Lexington Parkway North
File ID: RLH FCO 11-11

Dear Mr. Senn:

This is to confirm that on April 26, 2011 at the Property Code Hearing, Marcia Moermond, Legislative Hearing Officer recommended granting a .5-inch variance on the openable height of the egress window in the first floor bedroom and denying the egress window in the third floor bedroom measuring 11.5 inches high by 25 inches wide and granting an extension for 90 days to come into compliance.

If you wish to contest, the City Council public hearing is scheduled for Wednesday, May 18, 2011 at 5:30 p.m. in Room 300 Council Chambers.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
File

