

Hearing date
5/10/11 1:30

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 4-25-11

To FAX#: 6-8574

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To:	Mai Yang, Paralegal
Location:	Legislative Hearing Office City of St. Paul
Sender:	Daniel Schmidt / Tim Yannarelli St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of 4 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination


Attachments: Egress Window Non-Compliance Determination Form

→ 1097 ORANGE

→ 658 CHARLES

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.





CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-268-8688
FAX: 651-268-8574

DATE: 4-25-11

APPEAL PROPERTY ADDRESS: 1097 ORANGE
APPLICANT NAME: PUBLIC HEALTH (DAMIEL) PHONE NUMBER: 651-266-1143
ON BEHALF OF: TAMMIE NEUMENFELT

PERMIT NUMBER: _____
TYPE OF WINDOW: WOOD DOUBLE HUNG
NUMBER OF WINDOWS: 3

TOTAL GLAZED AREA: 7.3 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES
WIDTH OF OPENING: 22" DIFFERENCE FROM REQUIRED OPENING: COMPLIES
HEIGHT OF OPENING: 21 1/2" DIFFERENCE FROM REQUIRED OPENING: 2.5"
HEIGHT OF OPENING TO FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE):

FROM: _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 4-25-11

APPEAL PROPERTY ADDRESS: 658 CHARLES
APPLICANT NAME: PUBLIC HEALTH (DAMEZ) PHONE NUMBER: 651-266-1143


PERMIT NUMBER: _____
TYPE OF WINDOW: VINYL DOUBLE HUNG
NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.3 sqft DIFFERENCE FROM REQUIRED AREA: COMPLIES
WIDTH OF OPENING: 23" DIFFERENCE FROM REQUIRED OPENING: COMPLIES
HEIGHT OF OPENING: 19.93" DIFFERENCE FROM REQUIRED OPENING: 4.07"
HEIGHT OF OPENING TO FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): SEE EXHIBIT A

FROM: _____

EXHIBIT A



Subject & Model		Min. W: 11	Max. W: 43	Min. H: 28	Max. H: 14	Min. U: 132	Max. U: 232
(Model 0201) Excaltibur Double Hung							
Top Sash Width	24.2500	Width		Egress Size			
Top Sash Height	25.1200	27.5	27.5	53.375	53.375		
Bottom Sash Width	25.7500	Height		Egress Size			
Bottom Sash Height	26.1200						
Top Glass Width	22.625	Exhaustion		Exhaustion		Exhaustion	
Top Glass Height	22.4375	Opening: Exact Size		Opening: Exact Size		Opening: Exact Size	
Bottom Glass Width	23.5625	Type: Standard		Type: Standard		Type: Standard	
Bottom Glass Height	24.4375	Screen: 1/8"		Screen: 1/8"		Screen: 1/8"	
Screen Width	23.8125	Glass: Double Strength (2 mm)		Glass: Double Strength (2 mm)		Glass: Double Strength (2 mm)	
Screen Height	50.6000						
Top Sash Weight (Plus 5 lb)	20 lb	<input type="checkbox"/> w/ Sash Cabinet					
Top Balance Size (Spinal)	21.75						
Bottom Sash Weight	16 lb						
Bottom Balance Size (C.F.)	8 LG						
Bottom Balance Size (Spinal)	25.8R						
Egress Opening Width	23.0900						
Egress Opening Height	18.9075						
Egress Opening Area (sq.ft.)	3.1970						

* TOTAL GLAZED AREA

23.8 x 50.5 = 1202 = 144 = 8.3 sq ft