



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 1, 2010

Bruce Noyes
Dept of Public Health
2785 White Bear Ave N, Ste. 350
Maplewood, MN 55109

VIA FAX: 651-266-1177

Re: Appeal for property at 312 Burgess #1.
File ID: ALH 10-299

Dear Mr. Noyes:

This is to confirm that on October 28, 2010, Marcia Moermond, Legislative Hearing Officer reviewed your appeal in the above-referenced matter and recommended granting a 1-inch variance on the openable width of one double hung replacement egress bedroom window measuring 28 inches high by 19 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Paralegal

cc: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
Ryan Rehn (email)

