



# APPLICATION FOR APPEAL

RECEIVED  
MAY . . . . .  
CITY CLERK

RECEIVED Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
MAY 04 2011 Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560  
CITY CLERK

**The City Clerk needs the following to process your appeal:**

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>5-17-11</u>
Time <u>1:30</u>
<b>Location of Hearing:</b>
Room 330 City Hall/Courthouse

*mailed 5-4-11*

## Address Being Appealed:

Number & Street: 861 Albert St. N. City: St. Paul State: MN Zip: 55110

Appellant/Applicant: Charles R. Petrick Email chuck.petrick@vgpm.com

Phone Numbers: Business 651-428-0646 Residence none Cell 651-428-0646

Signature: *Charles R. Petrick* Date: 5/2/11

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

*see DEFICIENCY LIST - window is existing in structure & passed inspection previously. One window matches the min. sq. inches total.*

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989  
Saint Paul, MN 55101-1806 Fax: 651-266-8951

April 27, 2011

CHARLES R PETRICH  
5771 MEADOWVIEW DRIVE  
WHITE BEAR LAKE MN 55110-2290

*St Paul  
City Clerk*

*man with  
copy of  
permit*

*28 City  
87-12*

**FIRE CERTIFICATE OF OCCUPANCY  
APPROVAL WITH CORRECTIONS**

RE: 861 ALBERT ST N  
Ref. # 104234

Dear Property Representative:

Your building was inspected on April 27, 2011 for the renewal of the Fire Certificate of Occupancy and was approved. When the required fee has been paid you will receive your certificate. There are however seasonal or non-life safety deficiencies noted below which must be corrected prior to re-inspection.

The following deficiencies must be corrected immediately. A re-inspection will be made after Tuesday, May 31, 2011.

**DEFICIENCY LIST**

1. MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Main Floor North Bedroom  
30h x 16w - Openable  
30h x 16w - Glazed

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

If you have any questions, email me at: [mike.urmann@ci.stpaul.mn.us](mailto:mike.urmann@ci.stpaul.mn.us) or call me at 651-266-8990 between 7:30 a.m - 9:00 a.m.

Sincerely,

Michael Urmann  
Fire Inspector

Ref. # 104234