



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

*375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806*

*Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi*

October 29, 2013

BETH M JUTILA
SCOTT A JUTILA
11130 -- 243RD ST N
SCANDIA MN 55073-9651

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 977 HAZELWOOD ST
Ref. # 117410

Dear Property Representative:

Your building was determined to be a registered vacant building on October 29, 2013. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

DEFICIENCY LIST

1. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
2. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.
3. MSFC 304.1 - Remove excessive combustible storage and/or vegetation from exterior property areas.
4. SPLC 34.09 (1) b,c, 34.33 (1) b, c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.

5. MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.
6. MSMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work WILL require a permit(s). Call DSI at (651) 266-8989.
7. SPLC 34.11 (5), 34.34 (2) - Contact a licensed contractor to repair or replace the water heater. This work WILL require a permit(s). Call DSI at (651) 266-9090.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For **forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>**

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Inspector

Ref. # 117410