

✓Scanned



# APPLICATION FOR APPEAL

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED  
APR 24 2012  
CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, May 1, 2012

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 2101 BURNS AVE City: ST PAUL State: MN Zip: 55

Appellant/Applicant: JUSTIN NELSON Email: JDNELSONCONSTRUCTION@HOTMAIL.COM

Phone Numbers: Business 651-208-2716 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: 4-24-12

Name of Owner (if other than Appellant): STEVE HANSON

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

(2) EGRESS WINDOWS ON MAIN LEVEL

mailing: 5348 Cedarwood Ct.  
White Bear Township, MN 55110



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

## EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: April 24, 2012

APPEAL PROPERTY ADDRESS: 2101 BURNS AVE

APPLICANT NAME: J D NELSON CONSTRUCTION LLC

PHONE NUMBER: 651-208-2716

PERMIT NUMBER: 12 048515

TYPE OF WINDOW DOUBLE HUNG

NUMBER OF WINDOWS 2

<b>Total Glazed Area</b> Minimum 5 Square Feet	10.2	<b>Difference from Required Area</b>	+5.2
<b>Width of Opening</b> Minimum 20 Inches	37	<b>Difference from Required Opening</b>	+17
<b>Height of Opening</b> Minimum 24 Inches	17	<b>Difference from Required Opening</b>	-7
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	<48	<b>Difference from Maximum Height</b>	OK

COMMENTS: NA

Reviewed by: R REHN



CITY OF ST PAUL

Department of Safety and Inspections
375 Jackson Street, Suite 220
St Paul, Minnesota 55101-1806

GENERAL BUILDING PERMIT APPLICATION

Visit our Web Site at www.stpaul.gov/dsi

PROJECT ADDRESS: 2101 BURNS AVE ST PAUL
Contractor: J.D. NELSON CONSTRUCTION
Property Owner: STEVE HANSON
Architect: [Blank]

Select the Type of Work: Remodel/Alter
Select Applicable Installation Below: Windows: 2
Est. Start Date: 4-25, Est. Finish Date: 4-27, Total Value: \$12,000

Description of Project: 2 BEDROOM WINDOWS
Applicant certifies that all information is correct and that all pertinent state regulations and city ordinances will be complied with in performing the work for which this permit is issued.

Structure Dimensions (In Feet) table with columns: Width, Length, Height, Total Square Feet, Basement, # of Stories

Lot Dimensions (In Feet) table with columns: Lot Width, Lot Depth, Front, Back, Side 1, Side 2

For Office Use Only

Change/Expansion of Use? Yes / No
Existing Primary Use: SFD, Proposed Primary Use: SFD, Zoning District: R3

SUMMARY OF FEES table with rows: Building Permit Fee, Plan Check Fee, State Surcharge, SAC, SAC Processing Fee, Design Review Fee, Park Dedication Fee, Total Permit Fee

PLAN REVIEW REMARKS: PERMIT DENIED - WINDOWS DO NOT MEET EGRESS WINDOW POLICY. RR 4.24.12

S.A.C. #: [Blank], Reviewed By: [Blank], Date: [Blank], Warning Folder #: [Blank]

Total Permit Fee: \$ [Blank]

State Valuation: \$ [Blank], Vacant Bldg. Folder #: [Blank], PERMIT #: 12-048515

Signature of Cardholder (required for all charges):

Payment options: American Express, Discover, MasterCard, Visa
Expiration Month/Year: [Blank]

Enter Account Number: [Blank]