

RECEIVED

NOV 30 2011

CITY CLERK

APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560



Will
be
Coming
over
to
pay

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>12-6-11</u>
Time <u>1:30</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1270 Niles Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Scherer Window & Door Email: Chris Judd cjudd@scherecbros.com

Phone Numbers: Business 952-277-1685 Residence _____ Cell 612-290-7031

Signature: Chris Judd Date: 11/30/2011

Name of Owner (if other than Appellant): Gail Riddle

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/ Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

See Next Page



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: _____

APPEAL PROPERTY ADDRESS: 1270 Niles Ave

APPLICANT NAME: Chris Judd PHONE NUMBER: 952-277-1685

Cell: 612-290-7031

PERMIT NUMBER: Not Rec'd Yet

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 1

Egress
TOTAL GLAZED AREA: 3.93 sq-ft

DIFFERENCE FROM REQUIRED AREA: _____

Clear
WIDTH OF OPENING: 26 3/8"

DIFFERENCE FROM REQUIRED OPENING: Exceeds by 2 3/8"

Clear
HEIGHT OF OPENING: 21 7/16"

DIFFERENCE FROM REQUIRED OPENING: Misses by 2 9/16"

HEIGHT OF OPENING
TO FINISHED FLOOR: 30"

DIFFERENCE FROM MAXIMUM HEIGHT: Within Range

RECOMMENDATION (IF APPLICABLE): We are hoping this will satisfy requirements for MN State Fire Code.

FROM: _____