



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 1083 P. 3

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 6-6-12

APPEAL PROPERTY ADDRESS: 979 LAWSON AVE

St Paul-Ramsey Co. Public Health

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 266-1143

PERMIT NUMBER: \_\_\_\_\_

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 9.7' sq DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: 27" DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING: 19.87 DIFFERENCE FROM REQUIRED OPENING: 4.1"

HEIGHT OF OPENING TO FINISHED FLOOR: < 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE): \_\_\_\_\_

Jun. 6. 2012 3:37PM

FROM: \_\_\_\_\_