



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHOND: (651) 266-8560 FAX: (651) 266-8574

December 15, 2010

Dan Parker  
Custom Remodelers, Inc.  
obo Nhia Moua & Mai Vang-Moua  
474 Apollo Drive  
Lino Lakes MN 55014-0000

VIA EMAIL: [judy.h@customremodelersinc.com](mailto:judy.h@customremodelersinc.com)

Re: Appeal of Window Permit for property at 1351 Bradley Street  
File No. ALH 10-463

Dear Mr. Parker:

This is to confirm that on December 1, 2010 Marcia Moermond, the Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 6-inch variance on the openable height of three double hung replacement egress bedroom windows which measured at 18 inches high by 29 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang  
Legislative Hearing Coordinator

c: Fire Supervisors (email)  
Pat Fish (email)  
Jim Bloom (email)  
Ryan Rehn (email)  
Stephen Ubl (email)  
File