



APPLICATION FOR APPEAL

OCT 22 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Nov. 2

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 433 Wheelock Parkway W City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Beissel Window and Siding, Co. * Email: Jeff@beisselwindows.com

Phone Numbers: Business 651-451-6835 Residence _____ Cell _____

Signature: *Jeff W. Beissel* Date: 10/20/10

Name of Owner (if other than Appellant): Tom & Julie Sparrow

Address (if not Appellant's): 433 Wheelock Parkway West

Phone Numbers: Business _____ Residence 651-488-7703 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O see attached
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other Bedroom Egress Beissel Window and Siding, Co.
- Other 1635 Oakdale Avenue
- Other West ST. Paul, MN 55118



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 24, 2010

APPEAL PROPERTY ADDRESS: 433 WHEELLOCK PKWY W
APPLICANT NAME: BEISSEL WINDOW & SIDING CO
PHONE NUMBER: 651-266-9074
PERMIT NUMBER: 10 900692
TYPE OF WINDOW Double hung
NUMBER OF WINDOWS 1

Total Glazed Area	8.92	Difference from Required Area	+3.92
Width of Opening	28.65	Difference from Required Opening	+8.68
Height of Opening	21.25	Difference from Required Opening	-2.75
Height of Opening to Finished Floor	27	Difference from Maximum Height	ok

COMMENTS: With the information provided approval is recommended. 9-24-10 rr

Reviewed by: Rehn