



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

February 17, 2011

Daniel Schmidt
RC Public Health
2875 White Bear Ave N, Ste. 350
Maplewood MN 55109

VIA EMAIL: daniel.schmidt@co.ramsey.mn.us

Re: Appeal for property at 1017 Englewood Avenue
File ID: ALH 11-240

Dear Mr. Schmidt:

This is to confirm that on February 8, 2011, Marcia Moermond, Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a .625-inch variance on the openable height of one double hung replacement egress bedroom window which measured at 23.325 inches high by 27 inches wide.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
File

