

APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to pr		YOUR HEARING Date and Time:
\$25 filing fee payable to the City of S (if cash: receipt number)	oaint Paul	Tuesday, 1-18-2011
Copy of the City-issued orders or let	t BEGGENED	
are being appealed	IAM ()	Time / :30
are being appealed Attachments you may wish to include This appeal form completed	JAN U / 2011	Location of Hearing:
This appeal form completed	CITY CLERK	Room 330 City Hall/Courthouse
	and the second of the second o	walkin
Address Being Appealed:		
Number & Street: 792 Almy to	AveCity: \$\frac{A}{2}\$	Paul State: MN Zip: 55?
Appellant/Applicant: NI) & builders Email unfo While builder, com		
Phone Numbers: Business 551-222 470	Residence	Cell 651.335-9445
Signature: Dro Hills		Date: 1/6/2011
Name of Owner (if other than Appellant): Tok + Law &		
Address (if not Appellant's): 792 M	instan One	
Phone Numbers: Business	Residence	Cell 651-335-9445
What Is Being appealed and why? Attachments Are Acceptable		
Vacate Order/Condemnation/		
Revocation of Fire C of O		
□ Summary/Vehicle Abatement		
□ Fire C of O Deficiency List		
□ Fire C of O: Only Egress Windows		
□ Code Enforcement Correction Notice		
□ Vacant Building Registration		
Other	1). 1. (Andrew Control of the
□ Other	WINN ST	
□ Other		



CITY OF SAINT PAUL INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK 15 KELLOGG BLVD. WEST 310 CITY HALL SAINT PAUL, MN 55102

ROM: David Tank

PHONE: 651-266-8688 FAX: 651-266-8574

DATE: 1/7/11 APPEAL PROPERTY ADDRESS: 792 Arlington Ave. W. APPLICANT NAME: Willes Bldvs PHONE NUMBER: 651.335 9445 PERMIT NUMBER: TYPE OF WINDOW: _5/ider NUMBER OF WINDOWS: / TOTAL GLAZED AREA: 8 Syff DIFFERENCE FROM REQUIRED AREA: +356 OK WIDTH OF OPENING: _____ 26" DIFFERENCE FROM REQUIRED OPENING: +6"0 1C HEIGHT OF OPENING: 22" DIFFERENCE FROM REQUIRED OPENING: - 2 " HEIGHT OF OPENING TO FINISHED FLOOR: 55 DIFFERENCE FROM MAXIMUM HEIGHT: -7" Whichers are as big as contractor can make them with out refroming and redong the whole wall.