



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 15, 2011

Kenny Anderson
Midwest Exteriors Plus
o/b/o Mary Skarda

VIA EMAIL: kenny@midwestplus.com

RE: Appeal for property at 1255 Edmund Avenue

Dear Mr. Anderson:

This is to confirm that the Legislative Hearing Officer, Marcia Moermond, has reviewed the above-referenced matter and recommended that the City Council grant a 4-inch variance on the openable height of two insert/double hung replacement egress bedroom windows measuring 20.06 inches high by 25.34 inches wide.

The City Council Public Hearing is scheduled for Wednesday, December 7, 2011 at 5:30 p.m. in Room 300 Council Chambers. You don't need to attend this hearing.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Jim Bloom (email)
Stephen Ubl (email)