



APPLICATION FOR APPEAL

RECEIVED

OCT 12 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Oct. 19

Time 2:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 242 GOODRICH AVENUE City: SAINT PAUL State: MN Zip: 55102

Appellant/Applicant: RICHARD MILLER Email _____

Phone Numbers: Business 651-259-3152 Residence 651-280-0836 Cell _____

Signature: R. Miller Date: OCTOBER 12, 2010

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

October 4, 2010

RICHARD G MILLER
26 10TH STREET WEST #802
ST PAUL MN 55102

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 242 GOODRICH AVE
Ref. # 104977

Dear Property Representative:

Your building was determined to be a registered vacant building on October 4, 2010. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

DEFICIENCY LIST

1. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
2. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
3. SPLC 34.19 - Provide access to the inspector to all areas of the building.-Failure to provide access resulted in revocation of C of O.
4. SPLC 45.03 (6) - Cut and maintain the grass/weeds less than 8 inches tall.
5. SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.- Holes in wall on West side of structure.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: mike.cassidy@ci.stpaul.mn.us or call me at 651-266-8984 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mike Cassidy
Fire Inspector

Ref. # 104977