



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

April 5, 2011

Gerald Peterson
1795 Hillcrest Ave
St. Paul MN 55116

Re: Appeal for property at 1795 Hillcrest Avenue
File ID #: ALH 11-423

Dear Mr. Peterson:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 4.5-inch variance on the openable height of one double hung replacement egress bedroom window measuring 19.5 inches high by 24 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
File