

Saint Paul - Ramsey County Department of Public Health

Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 11/2/10 at 1:30

RECEIVED

OCT 22 2010

CITY CLERK

FACSIMILE TRANSMISSION

To FAX#: 6-8574

Cover Sheet and Transmittal Form.

To:	<u>Mai Varg, Paralegal</u>
Location:	<u>Legislative Hearing Office</u> <u>City of St. Paul</u>
Sender:	<u>Bruce Noyes / Tim Yannorelly</u> <u>St. Paul - Ramsey Cty. Dept. of Public Health</u>

This transmission consists of 5 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1142 (Bruce Noyes)

Message:

2 Requests for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form
(Manufacturers Window Specifications)
EXHIBIT A & B

2 Requests, 1 House (2 Bedrooms)

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.




EXHIBIT A

Select a Model: 0201 (Model 0201) Excalibur Double Hung P.P

Top Sash Width	20.4250
Top Sash Height	27.1675
Bottom Sash Width	21.4250
Bottom Sash Height	23.1675
Top Glass Width	18.7500
Top Glass Height	25.5000
Bottom Glass Width	19.7500
Bottom Glass Height	21.5000
Screen Width	19.5076
Screen Height	21.5000


Rated Glazed Area

Top Sash Weight (Plus 5 lb)	16 lb
Top Balance Size (C.F.)	3.94
Top Balance Size (Spiral)	23.68
Bottom Sash Weight	15 lb
Bottom Balance Size (C.F.)	3.16
Bottom Balance Size (Spiral)	27.48
Egress Opening Width	19.2880
Egress Opening Height	22.0000
Egress Opening Area (sq. ft.)	2.9440

Exterior: Sash Extrusion: <<< For Arch-Top Models Only
 Opening: Exact Size
 Type: Standard
 Screen: FM
 Glass: Double Strength (3 mm)

No Sash Obstruction

* $19.9 \times 54.6 = 1086.5 \div 144 = 7.55 \text{ sq. ft.}$



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/22

APPEAL PROPERTY ADDRESS: 726 Cook
SPAVL & RAMSEY
APPLICANT NAME: COUNTY PUBLIC HEALTH PHONE NUMBER: 266-1143
RUBY PARK 651-414-9329

PERMIT NUMBER: _____
TYPE OF WINDOW: _____
NUMBER OF WINDOWS: _____

TOTAL GLAZED AREA: 6.9 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES
WIDTH OF OPENING: 19.3" DIFFERENCE FROM REQUIRED OPENING: 0.7"
HEIGHT OF OPENING: 2.0" DIFFERENCE FROM REQUIRED OPENING: 4"
HEIGHT OF OPENING TO FINISHED FLOOR: < 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): SEE ATTACHED (EXHIBIT B)

FROM: _____

2 of 2

EXHIBIT B

Select a Model

(Model 0201) Excalibur Double Hung

0021

Top Sash Width	20.000
Top Sash Height	25.125
Bottom Sash Width	11.500
Bottom Sash Height	18.125
Top Glass Height	18.125
Bottom Glass Height	19.875
Screen Width	20.000
Screen Height	18.125
Top Sash Weight (Plus 8 lb)	17 lb
Bottom Sash Weight (Plus 8 lb)	17 lb
Top Balance Size (Sprail)	25-7R
Bottom Sash Weight	76N
Bottom Balance Size (C-F)	76N
Egress Opening Width	18.3440
Egress Opening Height	20.000
Egress Opening Area (sq.ft.)	2.6670

Width	23.75	Front Sash
Height	53.5	Back Sash

Extension: Select Extension
 Opening: Fixed Sash
 Type: Standard
 Screen: Roll
 Glass: Double Strength (3 mm)

At Sash Exterior

X / Y

* $20 \times 50 = 1,000 \div 144 = 6.9 \text{ sq ft.}$