


10/19/10
1:30pm



Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 10/4/10

RECEIVED

OCT 7 2010

To FAX#: 6-8574

CITY CLERK

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To: Mai Yang, Paralegal
 Location: Legislative Hearing Office
City of St. Paul
 Sender: Bruce Noyes / Tim Yannarelli
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1142 (Bruce Noyes)

Message:

Request for Egress Window Non-Compliance Determination
Attachments: 1.) Egress Window Non-Compliance Determination Form
2.) Window Specifications - Exhibit A

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/7/10

APPEAL PROPERTY ADDRESS: 174 CHARLES AVE #2, Uptown
ST PAUL RAMSEY COUNTY

APPLICANT NAME: DEPT. OF PUBLIC HEALTH PHONE NUMBER: 651-266-1142 (Ruce)
BUILDING OWNER: HRA and GREATER FREETOWN CDC, Becky Errigo, 651-749-748

PERMIT NUMBER: _____

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 8.7 sq. ft.

DIFFERENCE FROM REQUIRED AREA: Complies

WIDTH OF OPENING: 23.1 inches

DIFFERENCE FROM REQUIRED OPENING: Complies

HEIGHT OF OPENING: 21 inches

DIFFERENCE FROM REQUIRED OPENING: 3 inches

HEIGHT OF OPENING TO FINISHED FLOOR: Less than 48"

DIFFERENCE FROM MAXIMUM HEIGHT: Complies

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____

Exhibit A

Select a Model

(Model 0201)	
Excallbur Double Hung	
Top Sash Width	24.2500
Top Sash Height	28.1875
Bottom Sash Width	25.2500
Bottom Sash Height	27.1875
Top Glass Width	22.6625
Top Glass Height	24.5000
Bottom Glass Width	23.5625
Bottom Glass Height	25.5000
Screen Width	23.8125
Screen Height	62.8250
Total Glazed Area	
Top Sash Weight (Plus 6 lb)	20 lb
Top Balance Size (C.F)	33RD
Top Balance Size (Spiral)	21-7B
Bottom Sash Weight	17 lb
Bottom Balance Size (C.F)	9NAT
Bottom Balance Size (Spiral)	25-6R
Egress Opening Width	23.0940
Egress Opening Height	21.0000
Egress Opening Area (sq.ft.)	3.3680

Min. W: 11	Max. W: 12
Min. H: 20	Max. H: 132

	Width	Height
Exact Size	27.5	65.5

Extrusion: Select Extrusion << For Arch-Top Models Only

Opening: Exact Size

Type: Standard

Screen: Full

Glass: Double Strength (3 mm)

AC Sash Calculator

* $23.8 \times 52.6 = 1251.8 \div 144 = 8.7 \text{ sq. ft}$