



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

June 15, 2012

Erick Simola or Nicole Hanson
806 Parkway Drive
St. Paul, MN 55106

VIA EMAIL: erick440@yahoo.com AND US MAIL
Nicki Hanson, VIA EMAIL: hans2900@umn.edu

RE: 806 Parkway Drive appeal

Dear Mr. Simola or Ms. Hanson:

I am returning your appeal and the application fee of \$25.00. The sill height has met the requirement of the Legislative Code; therefore, there is no need for a variance by the Legislative Hearing Officer on this. The requirement for sill height is less than 48 inches and the sill height you have here is at 47 inches.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

MV

Mai Vang

Encl.

cc: Dori Dufesne (via email w/o encl)
Jim Bloom (email w/o encl)
Stephen Ubl (email w/o encl)