

✓ scanned

Fax: to Janie 266-8574

from - H/P Kalsow
Phone: 651-738-1273

2-3-11



APPLICATION FOR APPEAL

Saint Paul City Clerk
310 City Hall 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____) CR # 10161 12.50
City # 10606 12.50
 - Copy of the City-issued orders or letter which
are being appealed
 - Attachments you may wish to include
 - This appeal form completed
- Mailed 25.00
1-20-11

YOUR HEARING Date and Time:	
Tuesday,	2-8-11
Time	1:30
Location of Hearing: Room 330 City Hall/Courthouse	

Address Being Appealed:

Number & Street: 468 TOWER ST City: ST. PAUL State: MN Zip: 55119

Appellant/Applicant: HELENE KALSOW
PETRA L. KALSOW Email _____

Phone Numbers: Business _____ Residence 651/738-1273 Cell _____

Signature: Helene Kalsow Petra Kalsow Date: 2/3/11 2/3/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

0107381273 (REV)



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 13, 2011

APPEAL PROPERTY ADDRESS: 468 TOWER ST

APPLICANT NAME: LINDUS CONSTRUCTION INC

PHONE NUMBER: 651-266-9027

PERMIT NUMBER: 10 904839

TYPE OF WINDOW Glider

NUMBER OF WINDOWS Two

Total Glazed Area Minimum 5 Square Feet	11.7 sq. ft.	Difference from Required Area	+6.0 sq. ft.
Width of Opening Minimum 20 Inches	30"	Difference from Required Opening	+10"
Height of Opening Minimum 24 Inches	28"	Difference from Required Opening	+4"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	52.5"	Difference from Maximum Height	4.5"

COMMENTS: Recommend approval

Reviewed by: David Nelson

*#10161
#10606
12.50
12.50
25.00
enc.
1-20-11*