



APPLICATION FOR APPEAL

Saint Paul City Clerk

RECEIVED 310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

FEB 17 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 3-8-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 426 Mt Curve Blvd City: St. Paul State: MN Zip: 55

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: 02/09/11

Name of Owner (if other than Appellant): Jennifer Davis-Lammers

Address (if not Appellant's): 426 Mt Curve Blvd

Phone Numbers: Business _____ Residence 651-690-3518 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 1 replacement window that will not comply w/ egress requirements. An appeal has already been approved for this property; proposing a Casement window replacement. However we are unable to make the window proposed. The existing operation is Double Hung and this appeal is to gain approval of that style. Given sizes, please Approve



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 10, 2011

APPEAL PROPERTY ADDRESS: 426 MOUNT CURVE BLVD

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 11 009177

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	7.5 sq. ft.	Difference from Required Area	+ 2.5 sq. ft.
Width of Opening Minimum 20 Inches	20"	Difference from Required Opening	NA
Height of Opening Minimum 24 Inches	20 7/8"	Difference from Required Opening	- 3 1/8"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B. H.