



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

February 4, 2011

Brian Pergament
Pergola Trust, LLC
201 Western Ave N
St. Paul MN 55102

VIA FAX: 651-602-9155

Re: Appeal for property at 178 Summit Avenue
File ID: ALH 11-230

Dear Brian:

This is to confirm that on February 3, 2011, Marcia Moermond, Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a variance on the operable height and width of one casement replacement egress bedroom window which measured at 29 inches high by 20 inches wide. Your hearing date has been canceled.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
Patrick Tanner, Dorglass Inc
6008 Culligan Way, Minnetonka MN 55345 at patrickt@dorglass.com
File

