



APPLICATION FOR APPEAL

RECEIVED

OCT 20 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Oct 26

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1047 E Orange ^{Ave} City: St. Paul State: MN Zip: 55108

Appellant/Applicant: Renewal by Andersen Email: bryan.horton@randersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): David Peterson

Address (if not Appellant's): 1047 E ORANGE AVE ST. PAUL MN 55106

Phone Numbers: Business 651-736-4093 Residence 651-771-1300 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other

We are appealing windows that will be
short by 1" in operable height. All
other criteria will comply. Please Approve



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 18, 2010

APPEAL PROPERTY ADDRESS: 1047 ORANGE AVE E

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 911373

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 6

Total Glazed Area	12.7 sq. ft.	Difference from Required Area	+ 7.7 sq. ft.
Width of Opening	29"	Difference from Required Opening	+ 9"
Height of Opening	23"	Difference from Required Opening	- 1"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.