



# APPLICATION FOR APPEAL

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

RECEIVED

AUG 22 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

<i>YOUR HEARING Date and Time:</i>
Tuesday, <u>9-6-11</u>
Time <u>1:30</u>
<i>Location of Hearing:</i>
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1491 Dieter Street City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Mai Vang Email vangmai7@aol.com

Phone Numbers: Business 651-266-8563 Residence 651-793-4604 Cell 651-587-2427

Signature: Mai Vang Date: 8-22-11

Name of Owner (if other than Appellant): Same

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: August 22, 2011

APPEAL PROPERTY ADDRESS: 1491 DIETER ST

APPLICANT NAME: MAI VANG

PHONE NUMBER: 651-776-4258

PERMIT NUMBER: 11 243904

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Three

<b>Total Glazed Area</b> Minimum 5 Square Feet	2@ 8.25 sq. ft. 1@ 6.375 sq. ft.	<b>Difference from Required Area</b>	+2.55 sq. ft. +0.675 sq. ft.
<b>Width of Opening</b> Minimum 20 Inches	2@ 33" 1@ 27"	<b>Difference from Required Opening</b>	+13" +7"
<b>Height of Opening</b> Minimum 24 Inches	2@18" 1@17"	<b>Difference from Required Opening</b>	-6" -7"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	1@ 50"	<b>Difference from Maximum Height</b>	Exceeds by 2"

COMMENTS:

Reviewed by: David Nelson