



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

JAN 28 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 2-8-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1517 Old Hudson Rd. City: St Paul State: MN Zip: 55106

Appellant/Applicant: Anny DANG Email anny.dang@target.com

Phone Numbers: Business _____ Residence 651-774-2999 Cell 651-354-0537

Signature: Anny Dang Date: 1-28-11

Name of Owner (if other than Appellant): Anny Dang

Address (if not Appellant's): 691 Blair Ave St. Paul MN 55104

Phone Numbers: Business _____ Residence 774-2999 Cell 651-354-0537

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

all homes w/in this neighborhood contain similar window height and dimensions please help to approve my window. They were brand new windows from previous owners

Thank you Anny Dang
Revised 8/20/2010



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

January 24, 2011

ANNY DANG
691 BLAIR AVE
ST PAUL MN 55104-1651

FIRE INSPECTION CORRECTION NOTICE

RE: 1517 OLD HUDSON ROAD
Ref. #114911
Residential Class: B

Dear Property Representative:

Your building was inspected on January 24, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on March 21, 2011 at 2:00pm.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Dog License - SPLC 200.02 (a) No person shall own, harbor, keep or maintain in the City and dog over three months of age without a license. Provide written documentation of current license to the Fire Inspector. To obtain a dog license, contact DSI at 651-266-8989.

2. Egress Windows - Main Floor Bedrooms - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.

Main Floor Southeast, Northeast and Northwest Bedroom (Glider)

21.5h x 36w - Openable

18h x 74w - Glazed

Sill height is 58 inches

Note: It appears that these windows were originally awning style windows that have been replaced with glider type windows. There are no permits on file for the window replacements.

3. Garage - Fire Door - MSFC 703 - Provide, repair or replace the fire rated door and assembly. The minimum rating must be: -Replace the hollow core wooden door between the tuck-under garage and the basement and replace with a rated fire door. Provide a fire door that automatically closes and latches.
4. Garage - Throughout - MSFC 605.1 - Remove unapproved exposed wiring and install in accordance with the electrical code. This work may require a permit(s). Call DSI at (651) 266-9090.
5. Main Floor - Southeast and Northeast Bedrooms - MSFC 605.4 - Discontinue use of all multi-plug adapters.
6. Shed - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway. -Reposition the shed that is causing an exit obstruction to the main floor northeast bedroom egress window. The distance between the eave of the shed and the egress window is 18 inches.
7. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: wayne.spiering@ci.stpaul.mn.us or call me at 651-266-8993 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Wayne Spiering
Fire Inspector