



APPLICATION FOR APPEAL

RECEIVED

OCT 25 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number waived)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In Saxd

YOUR HEARING Date and Time:
Tuesday, <u>11-8-11</u>
Time <u>1:30</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1190 E Magnolia City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Richard Kedrowski Email rjkgunstinger@msn.com

Phone Numbers: Business (651) 430-0003 Residence _____ *Cell (612) 991-4474

Signature: Richard Kedrowski Date: 10/26/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 9340 Mendel Rd, Stillwater, MN 55082

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O Egress window non-compliance
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 25, 2011

APPEAL PROPERTY ADDRESS: 1190 MAGNOLIA AVE E
APPLICANT NAME: RICHARD L KEDROWSKI
PHONE NUMBER: 612-991-4474
PERMIT NUMBER: 11 292667
TYPE OF WINDOW Slider
NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	6.76 sq. ft	Difference from Required Area	+1.76 sq.ft.
Width of Opening Minimum 20 Inches	20.65"	Difference from Required Opening	+ .65"
Height of Opening Minimum 24 Inches	23.6"	Difference from Required Opening	- .4"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	Ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 10-25-11