

RECEIVED

DEC 06 2010

APPLICATION FOR APPEAL

CITY CLERK



Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 12/14/10

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1546 Case Ave City: St. Paul State: MAV Zip: 55106

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Lori Page

Address (if not Appellant's): 1546 Case Ave

Phone Numbers: Business _____ Residence 651-772-8571 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 1 replacement casement window that will not comply w/ Egress Policy. Other bedroom windows installed in 2009, wants to keep sizes/style consistent. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: December 2, 2010

APPEAL PROPERTY ADDRESS: 1546 CASE AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 929067
TYPE OF WINDOW Casement
NUMBER OF WINDOWS 1

Total Glazed Area	6.9 sq. ft.	Difference from Required Area	+ 1.9 sq. ft.
Width of Opening	17 7/8"	Difference from Required Opening	- 2 1/8"
Height of Opening	35 3/4"	Difference from Required Opening	+ 11 3/4"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B. H.