



# APPLICATION FOR APPEAL

RECEIVED  
OCT 20 2010  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>Oct. 26</u>
Time <u>1:30</u>
Location of Hearing:
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1352 Almond Ave City: St. Paul State: MN Zip: 55108

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: \_\_\_\_\_

Name of Owner (if other than Appellant): Julie Konop

Address (if not Appellant's): 1352 Almond Ave

Phone Numbers: Business \_\_\_\_\_ Residence 612-357-8357 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Current Dimensions will be 1/8" short in operable height. All other criteria will comply, homeowner wants to keep same style. Please Approve.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: October 18, 2010

APPEAL PROPERTY ADDRESS: 1352 ALMOND AVE  
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION  
PHONE NUMBER: 651-266-9071  
PERMIT NUMBER: 10 911368  
TYPE OF WINDOW: Double Hung  
NUMBER OF WINDOWS: 1

Total Glazed Area	14.5 sq. ft.	Difference from Required Area	+ 9.5 sq. ft.
Width of Opening	35 7/8 "	Difference from Required Opening	+ 15 7/8"
Height of Opening	22 7/8 "	Difference from Required Opening	- 1 1/8"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.