



APPLICATION FOR APPEAL

RECEIVED Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
MAY 31 2011 Saint Paul, Minnesota 55102
Telephone: (651) 266-8560
CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>6-7-11</u>
Time <u>1:30</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

mailed 6-1-11

Address Being Appealed:

Number & Street: 1311 Clarence St City: _____ State: _____ Zip: _____

Appellant/Applicant: Window World-Esther Dahl Email estherd@windowworldmn.com

Phone Numbers: Business 651-770-9315 Residence _____ Cell _____

Signature: _____ Date: 5/4/11

Name of Owner (if other than Appellant): Normxi Lee

Address (if not Appellant's): same as site

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other Asking for Variance on windows, _____
- Other _____
- Other _____

AMI ASSOCIATED MATERIALS INCORPORATED

WINDOW AND PATIO DOOR ORDER FORM
ALL PRODUCT CONFIGURATIONS MUST BE ORDERED AS VIEWED FROM THE EXTERIOR

FACTORY USE ONLY

Sold To: Norm Lee Ship To: Window World Twin Cities #86161
1311 Clarence St 2211 - 11th Ave East, Suite #130
52 Pal MW 57706 North St. Paul, MN 55109-5536
Lee Norm Ph: 651-770-9011, Fax (651) 770-0495

Date: 2-15-11 Pg 1 of 2
 Cust PO/Cust Name: 076-82164
 Job Name: Lee Norm

OPTION CODES:

Woodgrain Interiors	Exterior	Mull Type	Grid Options	Screen Options	ETC = Energy Tax Credit LEP = ClimatePlusElite	Glass Options
LO = Light Oak DO = Dark Oak CH = Cherry WH = White FX = Foxwood	AB = American Brown	2=Double 3=Triple Q=1/4, 1/2, 1/4 S=Special	A1=Colonial Flat Full A2=Colonial Flat Top Only A3=Colonial Flat Ends Only A4=Colonial Flat Center Only NOTE: For other grid options see back of form.	FS=Full Screen LS=Locking Screen NOTE: Fiberglass half screen are standard	LE = ClimateTech LEP = ClimateTech Plus LE2 = ClimateTech 2 NOTE: Grooved glass must be specified in instructions. See Price Book for style and availability	LEP = ClimateTech TG2 GT = Gray Tint BT = Bronze Tint LM = Laminated GR = Grooved Glass SC = Sunclean

NOTE: Hinge Left (HL) or Hinge Right (HR) on all casement orders as viewed from the exterior. Add "EH" for Egress Hinge.
ALL PRODUCT CONFIGURATIONS MUST BE ORDERED AS VIEWED FROM THE EXTERIOR.

LINE	QTY	MODEL	VINYL COLOR	W/DRN INT/EXT	WIDTH	HEIGHT	MULL TYPE	ROOM LOCATION	HINGE	GLASS OPTION	GRID OPTIONS STYLE PATTERN	OBS FULL	OBS BOTT	TEMP FULL	TEMP BOTT	SCREEN	FOAM WRAP	FOAM FILL	ORIEL DIM	GLASS BREAK	NAIL FIN	HDR EXPI
1	1	2001	WH		46 1/4	51 1/2		Kit	etc								X			X		X
2	1	2001			46 1/4	51 1/2			etc								X			X		X
3	1	2001			25	38 1/8			etc								X			X		X
4	1	1971			38 1/8	51 1/2	eh	Ball	L	le							X			X		X
5	1	2001			38 1/8	24 1/4		Ball		le							X			X		X
6	1	2002			78 1/4	24 1/4		Ball		le							X			X		X
7	1	2002			38 1/8	24 1/4				le							X			X		X
8	1	2002			38 1/8	24 1/4		Ball		le							X			X		X
9	1	2002			78 1/4	24 1/4				le							X			X		X
10	1	2001			31 5/8	37 3/8		base		le							X			X		X

SPECIAL INSTRUCTIONS:
All Windows DS Glass
 Line 5 Hinging- 0951 - le
 2-8-11 ERIC TT 2-9

SKETCHES
 1-4 & 9 HAVE METAL
 RETRORES IN NOW, NOT SURE
 what top of jamb will be like



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: April 22, 2011

APPEAL PROPERTY ADDRESS: 1311 CLARENCE ST

APPLICANT NAME: WINDOW WORLD

PHONE NUMBER: 651-770-5570

PERMIT NUMBER: 11 012520

TYPE OF WINDOW Glider

NUMBER OF WINDOWS TWO

Total Glazed Area Minimum 5 Square Feet	OK	Difference from Required Area	
Width of Opening Minimum 20 Inches	OK	Difference from Required Opening	
Height of Opening Minimum 24 Inches	OK	Difference from Required Opening	
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	58"	Difference from Maximum Height	+10"

COMMENTS:

Reviewed by: David Nelson