



APPLICATION FOR APPEAL

RECEIVED

DEC 01 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 12/14/10

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1872 Munster Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): John Larson & Katy Schutz

Address (if not Appellant's): 1872 Munster Ave

Phone Numbers: Business _____ Residence 651-230-3853 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 4 replacement double hung windows that will not comply w/ Egress. The opening sizes are included. The Homeowners would like to keep operating style consistent throughout the home. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 23, 2010

APPEAL PROPERTY ADDRESS: 1872 MUNSTER AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 926547
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 2

Total Glazed Area	10.5 sq. ft.	Difference from Required Area	+5.5 sq. ft.
Width of Opening	30"	Difference from Required Opening	+10"
Height of Opening	18 13/16"	Difference from Required Opening	- 5 3/16"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 23, 2010

APPEAL PROPERTY ADDRESS: 1872 MUNSTER AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 926547

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 2

Total Glazed Area	12.4 sq. ft.	Difference from Required Area	+ 7.4 sq. ft.
Width of Opening	30"	Difference from Required Opening	+ 10"
Height of Opening	22 3/4"	Difference from Required Opening	- 1 1/4"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.