

Scanned

RECEIVED

SEP 09 2011
CITY CLERK

APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560



The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include *mailed*
- This appeal form completed

YOUR HEARING Date and Time:	
Tuesday,	<u>9-20-11</u>
Time	<u>1:30</u>
Location of Hearing:	
<u>Room 330 City Hall/Courthouse</u>	

e-mailed 9-9-11

Address Being Appealed:

Number & Street: 1809 Princeton Ave City: St. Paul State: MN Zip: 55105

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: 09/06/11

Name of Owner (if other than Appellant): William Carroll

Address (if not Appellant's): 1809 Princeton Avenue

Phone Numbers: Business _____ Residence 651-699-3854 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 2 bedrooms with non-compliant bedroom windows. The first bedroom has a gliding window that is 4" short in height. The other bedroom double hung will be short by 5". Both comply w/ width and overall glazed area requirements. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 6, 2011

APPEAL PROPERTY ADDRESS: 1889 PRINCETON AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 272014


TYPE OF WINDOW: Gliding

NUMBER OF WINDOWS: 1

Total Glazed Area Minimum 5 Square Feet	6.3 sq. ft.	Difference from Required Area	+1.3 sq. ft.
Width of Opening Minimum 20 Inches	23"	Difference from Required Opening	+3"
Height of Opening Minimum 24 Inches	20"	Difference from Required Opening	-4"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	Ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 9-6-11



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 6, 2011

APPEAL PROPERTY ADDRESS: 1889 PRINCETON AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 272014

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	6.8 sq. ft.	Difference from Required Area	+1.8 sq. ft.
Width of Opening Minimum 20 Inches	26"	Difference from Required Opening	+6"
Height of Opening Minimum 24 Inches	18.875"	Difference from Required Opening	-5.125"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	Ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 9-6-11