



APPLICATION FOR APPEAL

RECEIVED
OCT 03 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, 10-11-11
Time 1:30
Location of Hearing: Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1635 Hartford Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Dan Bagenstoss

Address (if not Appellant's): 1635 Hartford Ave

Phone Numbers: Business _____ Residence 651-699-1540 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 1 replacement double hung that is located in an upper level attic. The room is being converted to be used for sleeping purposes. Changing the operation of the current window will decrease the openable width substantially. Double hung is the best option for the largest egress opening. Please Approve.

Revised 8/20/2010



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 27, 2011

APPEAL PROPERTY ADDRESS: 1635 HARTFORD AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 281110
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 1

Total Glazed Area Minimum 5 Square Feet	6.4	Difference from Required Area	+1.4
Width of Opening Minimum 20 Inches	22	Difference from Required Opening	+2
Height of Opening Minimum 24 Inches	21 1/8	Difference from Required Opening	-2 7/8
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	ok

COMMENTS: NA

Reviewed by: Rehn