



APPLICATION FOR APPEAL

RECEIVED
APR 21 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>5-3-11</u>
Time <u>1:30</u>
Location of Hearing:
Room 330 City Hall/Courthouse

walk-in

Address Being Appealed:

Number & Street: 610 Edmund Ave City: St Paul State: MN Zip: 55104

Appellant/Applicant: DRB #24 LLC Email _____

Phone Numbers: Business 612-720-1451 Residence _____ Cell 952-292-5744

Signature: [Signature] Date: 4.21.11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows Window meets 24x20 size
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 11, 2011

DRB 24 LLC
1020 DAVERN ST
ST PAUL MN 55116-2438

FIRE INSPECTION CORRECTION NOTICE

RE: ~~610 EDMUND AVE~~

Dear Property Representative:

Your building was inspected on April 11, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on May 11, 2011 at 10 am. ✓ Cal.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Exterior - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the doors in good condition.
2. Exterior - SPLC 34.08 (3) - Provide and maintain suitable ground cover on all exterior areas to control erosion.
3. ✓ Exterior-Garage - SPLC 34.09 (3) i - Repair and maintain an approved one-inch throw single cylinder deadbolt lock.
4. Interior - SPLC 34.12 (2), 34.35 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition.-Repair the loose bedroom door knob. -

4/14/11
CC: tm R ✓

5. Interior - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-The upper front window measured 20H x 24W.
6. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: lisa.martin@ci.stpaul.mn.us or call me at 651-266-8988 between 6:30 a.m. - 8:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Lisa Martin
Fire Inspector