

CITY OF SAINT PAUL

OFFICE OF THE CITY COUNCIL 310 CITY HALL 15 WEST KELLOGG BOULEVARD SAINT PAUL, MN 55102-1615

EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

April 12, 2011

Scott Pierson Champion Window Company of Minneapolis LLC 5100 Hwy 169 N - #B New Hope MN 55428

VIA EMAIL: spierson@championfactorydirect.com

Re: Appeal for property at <u>1338 Fifth Street East</u>

File ID #: ALH 11-450

Dear Mr. Pierson:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 4.25-inch variance on the openable height of one double hung replacement egress bedroom window measuring 19.75 inches high by 35.5 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang Legislative Hearing Coordinator

cc: Fire Supervisors (email)

Pat Fish (email) Jim Bloom (email) Stephen Ubl (email)

File