



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

March 15, 2011

Dan Schmidt
RC Dept of Public Health
2785 White Bear Ave N, Ste. 350
Maplewood, MN 55109

Re: Appeal for property at 1147 Magnolia Avenue East
File ID #: ALH 11-347

Dear Mr. Schmidt:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 3.94-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 20.06 inches high by 23.2 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
File