

INSPECTION REQUEST

Address this form to: MAILING LIST - FORM4 (District Chief, Deputy Chiefs and Yourself).

Date:	24 OCT 17	
Property Address:	1464 MINNEHAHA AVE	
Owner Name:	RYAN KEMPENICH	
Owner Phone:	612.986.1896	
Owner Address:	SAME	
Occupant Name:	SAME	
Occupant Phone:	SAME	
Check the following corrections:		
☐ Address Nos. ☒ Exit Doors ☐ Housekeeping ☒ Keybox ☐ Sprinkler System	☐ Hydrants ☐ Hazardous Material ☐ Fire Alarm System ☒ Smoke Detector ☐ Standpipe	☐ Fire Lane ☐ Electrical ☒ Fire Extinguishers ☐ Heating Plant ☐ Welding ☒ <u>OTHER EXIT LIGHTING, EMERGENCY LIGHTING, HAND RAILS, MEANS OF EGRESS</u>
Check the type of property:	☐ Single family or duplex ☒ Multi family (3 Units or more) ☐ Commercial	
Describe:	UPON ARRIVAL, S2 RECOGNIZED THE SINGLE FAMILY DWELLING HAS BEEN CONVERTED TO MULTIPLE APT UNITS. THERE APPEARS TO BE INCONSISTENT PLACEMENT OF SMOKE DETECTORS IN COMMON AREAS, LACK OF FIRE EXTINGUISHERS, EMERGENCY LIGHTING, EXIT SIGNS, HAND RAILS, AND POSSIBLY MAY NEED A KEY BOX.	
Name: DD JONES	Rank: CAPTAIN	Company: SQ2
Response:		
Name:	Date:	Phone: