



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8888  
FAX: 651-266-8574

DATE: 4-24

APPEAL PROPERTY ADDRESS: 1170 Jessie #2

APPLICANT NAME: PUBLIC Health (Daniel Schmidt) PHONE NUMBER: 266-1143

PERMIT NUMBER: \_\_\_\_\_

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 8.6 sq ft DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: 19.2" DIFFERENCE FROM REQUIRED OPENING: 0.8"

HEIGHT OF OPENING: 26" DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING ABOVE FINISHED FLOOR: 248" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE): \_\_\_\_\_

RECEIVED

APR 24 2012

CITY CLERK

FROM: \_\_\_\_\_

No. 0443 P. 12

Public Health

Ramsey Co.

St Paul

1:17PM  
Apr. 24. 2012

Select a Model		Min. W: 12	Max. W: 52
(Model 0201) Excaltibur Double Hung		Min. H: 23	Max. H: 44
			Max. U: 132
Top Sash Width	20.3750	Exact Size	
Top Sash Height	31.1875	Width: 23.625	23.625
Bottom Sash Width	21.3750	Height: 65.5	65.5
Bottom Sash Height	32.1875		
Top Glass Width	18.6875	Extrusion: <input type="text" value="Select Extrusion"/> << For Arch-Top Models Only	
Top Glass Height	28.0000	Opening: <input type="text" value="Exact Size"/>	
Bottom Glass Width	19.6875	Type: <input type="text" value="Standard"/>	
Bottom Glass Height	28.5000	Screen: <input type="text" value="Full"/>	
Screen Width	19.9375	Glass: <input type="text" value="Double Strength (2 mm)"/>	
Screen Height	42.3250		
Top Sash Weight (Plus 5 lb)	21 lb	<input type="checkbox"/> AC Sash Calculator	
Top Balance Size (C.F.)	6EBU		
Top Balance Size (Spiral)	27-SR		
Bottom Sash Weight	18 lb		
Bottom Balance Size (C.F.)	9NAT		
Bottom Balance Size (Spiral)	30-SR		
Egress Opening Width	19.2190		
Egress Opening Height	26.0800		
Egress Opening Area (sq.ft.)	3.4700		

1178 Jessie #2