

705 Magnolia Ave screen dryer vent

You don't often get email from kvang3570@yahoo.com. [Learn why this is important](#)

Think Before You Click: This email originated **outside** our organization.

7th email. This is with Aaron in mechanics

[Sent from Yahoo Mail for iPhone](#)

Begin forwarded message:

On Wednesday, May 22, 2024, 7:06 AM, Aaron Havlicek <Aaron.Havlicek@ci.stpaul.mn.us> wrote:

Hello,

From the photos I do not see any supports on the combustion air duct. Also it's a little hard to tell what I am looking at in the last two photos, if that is the dryer vent hood the screen and plastic cover need to be removed



SAINT PAUL
MINNESOTA

Aaron Havlicek

he/him/his

Mechanical Inspector
Department of Safety and Inspections
Suite 220
375 Jackson Street
Saint Paul, MN 55102

P: 651-266-9043

aaron.havlicek@ci.stpaul.mn.us



From: kelly vang <kvang3570@yahoo.com>

Sent: Tuesday, May 21, 2024 5:37 PM

To: Clint Zane <Clint.Zane@ci.stpaul.mn.us>

705 Magnolia Ave screen dryer vent

Cc: Aaron Havlicek <Aaron.Havlicek@ci.stpaul.mn.us>

Subject: Re: 705 magnolia ave screen for dryer vent

Think Before You Click: This email originated **outside** our organization.

705 Magnolia Ave screen dryer vent



705 Magnolia Ave screen dryer vent



705 Magnolia Ave screen dryer vent



705 Magnolia Ave screen dryer vent



705 Magnolia Ave screen dryer vent

On Tuesday, May 14, 2024, 2:39 PM, Clint Zane <Clint.Zane@ci.stpaul.mn.us> wrote:

Kelly,

I was out there today to verify the exterior dryer vent cover was ok, it looked good. I have already approved that you insulated it.

Could you please get me pictures of the sealed inside of the abandoned basement dryer vent and the supported combustion air duct? Aaron the mechanical inspector is waiting on these items, he may still want to see it in person, I have CC'd him here. These are the only outstanding items left.

Thanks,



Clint Zane

Code Compliance Officer

Building Inspector

Department of Safety and
Inspections

375 Jackson Street, Suite 300
Saint Paul, MN 55101

P: 651-266-9029

C: 651-248-3860

Clint.Zane@ci.stpaul.mn.us



Making Saint Paul the Most Livable City in
America

DSI's Mission: "To preserve and improve the quality of life in Saint Paul by protecting and promoting public health and safety for all."

From: kelly vang <kvang3570@yahoo.com>

Sent: Monday, May 13, 2024 9:45 AM

705 Magnolia Ave screen dryer vent

To: Clint Zane <Clint.Zane@ci.stpaul.mn.us>

Subject: 705 magnolia ave screen for dryer vent

Think Before You Click: This email originated **outside** our organization.

705 Magnolia Ave screen dryer vent



705 Magnolia Ave screen dryer vent

