



APPLICATION FOR APPEAL

RECEIVED

APR 15 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 5-3-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

mailed 4-15-11

Address Being Appealed:

Number & Street: 1861 Juliet City: ST Paul State: MN Zip: 55105

Appellant/Applicant: Tom Martinson Email Tmartinson@live.com

Phone Numbers: Business _____ Residence _____ Cell 612 964-6320

Signature: *Tom Martinson* Date: 4/13/2011

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 245 Luisa Ct Chaska MN 55318

Phone Numbers: Business _____ Residence _____ Cell 612 964-6320

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Deficiency List item #1 Provide & maintain an approved escape window from each sleeping room. I Am Appealing this only because the room in question is the attic of the home and not used as a bedroom. Although it is finished it has not heat vents and not functional for anything other than storage. The room is new & has been totally empty.

My son lives in this house with 1 roommate.

Revised 8/20/2010



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 8, 2011

THOMAS J MARTINSON
245 Luisa Ct
Chaska MN 55318-1996

FIRE INSPECTION CORRECTION NOTICE

RE: 1861 JULIET AVE
Residential Class: B

Dear Property Representative:

Your building was inspected on April 8, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on May 5, 2011 at 10:00 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Second floor - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-

Double hung window
16 h x 20.5 w Glazed 4.5 sq ft

DISPUTE

This Room is the attic & Not used as a bedroom



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

**SMOKE AND CARBON MONOXIDE DETECTOR
INSPECTION AFFIDAVIT**

**** This affidavit must be completed and returned to the fire inspector upon inspection of the property. A certificate of occupancy cannot be issued/renewed without this completed affidavit. If all the units were not inspected by one person, signatures of all persons inspecting are required. More than one sheet may be used. ****

1861 Juliet Ave 1 _____
Address # of Units C of O #

I affirm that I have given the occupant of each dwelling unit or guest room in the building at the above address a written explanation of the following:

1. The location and operation of each smoke detector and carbon monoxide detector.
2. Instructions describing the action to be taken when an alarm sounds.
3. The procedures for testing the detectors.
4. Who to contact when a low-battery tone sounds or power light fails.
5. The penalties for disabling smoke detection or carbon monoxide detection.

Signature: Date: 4/5/11

I affirm that I personally inspected the smoke detectors and carbon monoxide detectors in the dwelling units and guest rooms in the building at the above address as follows and that all detectors were in place and good working order:

Apt. #	Apt. #	Apt. #	Apt. #	Apt. #	Apt. #
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Signature: Date: 4/5/11

Minnesota State Statutes 299F.362 requires smoke detectors and Minnesota State Statute 299F.50 requires carbon monoxide detectors and Saint Paul Ordinance 39.02 (c) requires that an affidavit stating that “all detectors are inspected and serviced when needed and are operational be filed before a Certificate of Occupancy can be issued or renewed.”

Revised 12/09

Done
1/11
2010

Done

Done

2. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
3. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
4. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector