



APPLICATION FOR APPEAL

RECEIVED
FEB 24 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, MARCH 6, 2012

Time 1:30pm

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 336 Maple St City: St Paul State: MN Zip: 55106

Appellant/Applicant: Marpe Development + HPC Email: Mark@marpedevelopment.com

Phone Numbers: Business 651-226-5060 Residence " " Cell 651-226-5060

Signature: [Signature] Date: 2-22-12

Name of Owner (if other than Appellant): Mark Pasvogel Jr

Address (if not Appellant's): 2233 Hameline Ave E Roseville MN 55391

Phone Numbers: Business 651-226-5060 Residence " " Cell " "

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

(Windows)
This is a Historical Preservation Project. The HPC and Marpe Development are requesting to keep the historical integrity to this beautiful house.
Thank You.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574


DATE: February 22, 2012

APPEAL PROPERTY ADDRESS: 336 MAPLE ST
APPLICANT NAME: POLLOCK CONSTRUCTION LLC
PHONE NUMBER: 612-366-2674
PERMIT NUMBER: 11 299658
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	6.25"	Difference from Required Area	+ .7"
Width of Opening Minimum 20 Inches	16"	Difference from Required Opening	-4"
Height of Opening Minimum 24 Inches	29"	Difference from Required Opening	+5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	Ok

COMMENTS: N/A

Reviewed by: J Hoffman 2-22-12



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 22, 2012

APPEAL PROPERTY ADDRESS: 336 MAPLE ST

APPLICANT NAME: POLLOCK CONSTRUCTION LLC

PHONE NUMBER: 612-366-2674

PERMIT NUMBER: 11 299658

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	7	Difference from Required Area	+1.3
Width of Opening Minimum 20 Inches	18"	Difference from Required Opening	-2"
Height of Opening Minimum 24 Inches	29"	Difference from Required Opening	+5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	OK

COMMENTS: N/A

Reviewed by: J Hoffman 2-22-12