



APPLICATION FOR APPEAL

RECEIVED

NOV 09 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 11/16/10

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2078 Highland Parkway City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: 11/03/10

Name of Owner (if other than Appellant): John Kirr

Address (if not Appellant's): 2078 Highland Parkway

Phone Numbers: Business _____ Residence 62-743-0852 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 2 replacement double hung windows that will not comply w/ Egress Policy. The current openings will be 1" short in operable height and will exceed operable width by 5" and overall glazed area for the opening is 10.8 sqft. Please Approve



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 2, 2010

APPEAL PROPERTY ADDRESS: 2078 HIGHLAND PKWY
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 917636
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 2

| | | | |
|-------------------------------------|--------------|----------------------------------|---------------|
| Total Glazed Area | 10.8 sq. ft. | Difference from Required Area | + 5.8 sq. ft. |
| Width of Opening | 25" | Difference from Required Opening | + 5" |
| Height of Opening | 23" | Difference from Required Opening | - 1" |
| Height of Opening to Finished Floor | NA | Difference from Maximum Height | NA |

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.