



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

NOV 17 2010

CITY CLERK

1. Address of Property being Appealed: <u>105 W ROSE ST</u>	2. Number of Dwelling Units: <u>1</u>	3. Date of Letter Appealed: <u>11-15-10</u>
--	--	--

4. Name of Owner: Bob & Lynn Connolly
Address: 105 W ROSE ST City: ST PAUL State: MN Zip: 55101
Phone Numbers: Business _____ Residence 651-488-4052 Cellular 651-329-5430
Signature: Robert A. Connolly

5. Appellant / Applicant (if other than owner): Progressive Construction homebuilding
Address: 8160 Carman City: INVER HIGGS State: MN Zip: 55076
Phone Numbers: Business 651-455-9462 Residence _____ Cellular 651-248-3807
Signature: _____

6 State specifically what is being appealed and why (Use an attachment if necessary):

Egress Windows. Size Change Dimensions Length
and height I have the size I need but
I have ~~it is~~ 28 width and 20' height
if we reverse the height and width it will pass

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>11/17/10</u>	Fee Received: <u>25 cash</u>	Receipt Number:	Date of Hearing: <u>11/30/10</u> <u>at 1:30</u>
-----------------------------------	---------------------------------	-----------------	---



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 15, 2010

APPEAL PROPERTY ADDRESS: 105 ROSE AVE W

APPLICANT NAME: PROGRESSIVE CONSTRUCTION HOMEBUILDING
INC

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 907504

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3

Total Glazed Area	8	Difference from Required Area	+3
Width of Opening	27 ³ / ₄	Difference from Required Opening	+7 ³ / ₄
Height of Opening	21	Difference from Required Opening	-3
Height of Opening to Finished Floor	36	Difference from Maximum Height	ok

COMMENTS: na

Reviewed by: Rehn