



# APPLICATION FOR APPEAL

RECEIVED  
JAN 23 2012  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>2-7-12</u>
Time <u>1:30</u>
<b>Location of Hearing:</b>
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1345 Payne City: ST Paul State: MI Zip: 55130

Appellant/Applicant: Robert J Olsen Email BOJ Olsen @ Hot mail .com

Phone Numbers: Business 651 270 7619 Residence 651 714 8645 Cell \_\_\_\_\_

Signature: [Signature] Date: 1-23-12

Name of Owner (if other than Appellant): Same

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows Origin window in House
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989  
Saint Paul, MN 55101-1806 Fax: 651-266-8951

January 17, 2012

ROBERT J OLSEN  
GLENDA OLSEN  
2190 MAILAND ROAD  
ST PAUL MN 55119-5330

## CORRECTION NOTICE - RE-INSPECTION COMPLAINT

RE: 1345 PAYNE AVE  
Ref. # 102095

Dear Property Representative:

You are hereby notified that the following deficiencies must be corrected immediately. A reinspection will be made on or after February ~~3~~ 2012. *74*

Failure to comply may result in a criminal citation or the revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

### DEFICIENCY LIST

1. 2nd Floor - East and South bedrooms. - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Double hung window openings.  
Height 19.5 in. - Width 26 in.  
Glazed area.  
Height 40 in. - 23 in.
2. 2nd Floor - West bedroom - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Double hung window opening.  
Height 19.5 in. - Width 34 in.  
Glazed area.  
Height 40 in. - Width 31 in.

**You have the right to appeal these orders Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, St Paul Mn 55102 Phone 651 - 266-8688 and must be filed within 10 days of the date of order.**

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

If you have any questions, email me at [mike.cassidy@ci.stpaul.mn.us](mailto:mike.cassidy@ci.stpaul.mn.us) or call me at 651-266-8984 between 7:30 a.m - 9:00 a.m.

Please help to make Saint Paul a safer city in which to live and work.

Sincerely,

Mike Cassidy  
Fire Inspector

Ref. # 102095