

STAMP - Activities

[New Search](#)
[Help using this report](#)

Run Date: 04/03/19 09:58
AM

Sort by Most Recent Date

Starting Date:

House#:

Folder

Ending Date:

**Street
Name:**

Type: ▼

Folder Count: 601

**Include Same PIN
Addresses: Yes**

Click on [address link](#) to access
GISmo, MapIT, and Ramsey County Info

Click on [ID# link](#) below to view detail

PIN:282923330009

Address	In Date	ID #	Status	Type	Description
<u>755 PRIOR AVE N UNIT 001 - Mitch Iburg Ceramics</u>					
	02/27/2019	19 014777	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Add/Relocate 10 heads to conform to new walls in corridor to conform to NFPA 13 2010.
<u>755 PRIOR AVE N UNIT 002A - Vacant</u>					
	03/20/2019	19 020807	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - MANAGE INFINITY (T#10195) (1) NEW 100A PANEL
<u>755 PRIOR AVE N UNIT 002B - Vacant</u>					
	04/03/2019	19 027594	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - INTERACT SUITE #002B (T#10312) ROUGH IN REQUIRED FOR ADDING (15) NEW CIRCUITS
	03/20/2019	19 020688	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING IN NEW 100A PANEL WITH 10 CIRCUITS
<u>755 PRIOR AVE N UNIT 006B - TM Finishes</u>					
	12/13/2018	18 131127	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - TERRANCE MANN FINISHES LOWER LEVEL REFINISH DOORS STE 006B T#9792, 9793 & 9794
<u>755 PRIOR AVE N UNIT 104 - Party Room</u>					
	10/22/2018	18 115654	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - 100amp feeder and panel 2 heat pump connections Misc lighting and receptacles
	10/22/2018	18 115648	Abandoned	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - 100amp panel/feeder, connections to 2 heat pumps, misc. lighting and receptacles. 1st floor Suite 104
	10/22/2018	18 115645	Abandoned	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - Connect 2 heat pumps, lighting, receptacles and 100amp service. 1st Floor-Suite 104
	10/22/2018	18 115637	Abandoned	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - Connect 2 heat pumps, lighting, receptacles and 100amp service. 1st Floor-Suite 104
<u>755 PRIOR AVE N UNIT 106 - Party Room</u>					
	03/28/2019		Active/Issued		

	19 025851		E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - UP SWING CREATIVE SUITE 106 (T#10196) RELOCATING OF OUTLETS & SWITCHES
<u>755 PRIOR AVE N UNIT 235A - Vacant</u>				
03/20/2019	19 020906	Pending	XW - ECLIPS License - Water/Health - Health/Sport Club	Licensee Jennifer Marie Halstead Strength Collective - ECLIPS License# 20190000697
<u>755 PRIOR AVE N UNIT 237 - Minnesota Ice</u>				
03/28/2019	19 025841	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - MN ICE FREEZER SUITE 237 (T#10196) ADDING NEW SERVICE EQUIPMENT & CIRCUITS
03/20/2019	19 020700	Finald	E - Electrical Permit - Smoke Detector Only - Commercial Repair/Alter	Contractor Retrofit Electric - MN ICE (FRONT VESTIBLE) T#10195 ADDING (5) NEW CIRCUITS FOR WASHER & DRYER
<u>755 PRIOR AVE N - Silgan Containers Corp</u>				
03/29/2019	19 026430	Under Review	B - Building Permit - Commercial - Remodel	Contractor Rod Mussen - INTERACT ART STORAGE UNIT 002D INSTALLATION OF DOORS AND HARDWARE. PLUMBING, ELECTRICAL, AND MECHANICAL UNDER SEPARATE PERMIT.
03/27/2019	19 025795	Scheduled	SZ - Sports and Health Club - Medium Risk - Routine Inspection	Establishment Jennifer Halstead Halstead FitnessLLC, DBA Strength Collective
03/21/2019	19 021223	Pending	BS - Billboard / Sign - Signs - Commercial New	Contractor Dave Peliter Vector Sign Solutions Llic - SUITE #200 COPY TO READ: "College Possible" located on Southeast corner of building, visible from Prior Ave.
03/21/2019	19 021200	Pending	BS - Billboard / Sign - Signs - Commercial New	Contractor Dave Peliter Vector Sign Solutions Llic - COPY TO READ: 3 Projecting: Red Lot, Blue Lot, Yellow Lot 2 Wall multi tenant signs 3 projecting signs visible from Prior and 2 new wall signs on the south east corner of the building - one on each side of the corner.
03/21/2019	19 021100	Active/Issued	B - Building Permit - Commercial - Remodel	Contractor Ryan M Square LLC - SUITE 106 ADDING CONFERENCE ROOM TO EXISTING OFFICE SPACE PRIOR LOFTS
03/21/2019	19 020997	In Process	RF - Referral - C of O	Owner 755 N Prior Ave Llc/C/O Orton Development Inc - Follow up on C of O folder approved with corrections.
03/21/2019	19 020996	Pending	CO - Certificate of Occupancy - Assembly	Responsible Party Rod Musson 755 Prior LLC - Attn: Property Manager
03/20/2019	19 020799	Inspected	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - STRENGTH COLLECTIVE (T#10195) (3) NEW SERVICE EQUIPMENT & 75 KVA TRANSFORMER
03/20/2019	19 020754	Inspected	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL ONE SINK, ONE (1) 6- GALLON ELECTRIC WATER HEATER AND ASSOCIATED

03/20/2019	19 020750	Under Review	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	WASTE, VENT AND CW & HW PIPING Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL DUCTWORK FROM TWO (2) 2-1/2 TON WATER SOURCE HEAT PUMPS
03/20/2019	19 020746	Active/Issued	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL TWO (2) 2-1/2 TON HORIZONTAL WATER SOURCE HEAT PUMPS. EXTEND CWS & CWR FROM EXISTING MAINS. EXTEND CD TO EXISTING.
03/20/2019	19 020739	Active/Issued	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDNG #8 INSTALL ONE (1) ROOF EXHAUST FAN & ASSOCIATED DUCTWORK TO EXHAUST NEW SHOWER ROOMS. EXTEND SA DUCTWORK FROM EXISTING ROOFTOP UNIT TO SERVE NEW SHOWER ROOMS.
03/20/2019	19 020732	Active/Issued	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDING #8, INSTALL THREE (3) SHOWERS, THREE (3) FLOOR DRAINS, AND A GAS WATER HEATER
03/20/2019	19 020727	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - BUILDING 12 1ST FLOOR (T#10195) ADDING (3) NEW CIRCUITS IN SHOWER ROOM
03/14/2019	19 019322	Issued	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - add two pendent heads to new ceiling in "651Media" space.
03/08/2019	19 017411	Under Review	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 235C - HALSTEAD FITNESS - INSTALLATION OF DOORS AND HARDWARE. PLBG, ELECTRICAL & MECHICAL UNDER SEPARATE PERMIT.
03/08/2019	19 017407	Under Review	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 002A - MANAGE INFINITY - INSTALLATION OF DEMISING WALLS, OFFICE WALLS AND DOORS. PLBG, ELECTRICAL & MECHANICAL UNDER SEPARATE PERMIT.
03/08/2019	19 017403	Under Review	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 006B - INSTALLATION OF DOORS. PLBG, ELECTRICAL & MECHANICAL UNDER SEPARATE PERMIT.
03/08/2019	19 017400	Under Review	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 235H - INSTALLATION OF DEMISING WALLS, LOFT, STAIRS AND DOORS. PLBG, ELECTRICAL AND MECHANICAL UNDER SEPARATE PERMIT
03/08/2019	19 017350	Inspected	M - Mechanical Permit - Refrigeration - Commercial Replace	Contractor Craig Welna Total Refrigeration Systems - Minnesota Ice - SET UP W/I FREEZER AND HANG 2

				EVAPORATORS. TOTAL BTU - 100,000
02/28/2019	19 014839	Pending	CL - Compliance Checks - Liquor Compliance Check	Licensee Flanneljax's - ECLIPS License# 20180002381
02/26/2019	18 081078	Active/Issued	XL - ECLIPS License - Liquor - Liquor On Sale - Sunday	Licensee Flanneljax's - ECLIPS License# 20180002381
02/12/2019	19 010437	Inspected	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING 100 AMP PANEL WITH NEW BREAKERS (T#10043) MEGAN ENGSETH PHOTOGRAPHY STE303A
02/12/2019	19 010435	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING 100 AMP PANEL WITH NEW BREAKERS (T#10043)
02/07/2019	19 009400	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - UNIT #104A (MEGAN ENGSETH PHOTOGRAPHY) INSTALLATION OF DEMISING WALLS , PAINT, INSTALL DOORS, PLUMBING ELECTRICAL & MECHANICAL UNDER SEPARATE PERMITS
02/07/2019	19 009221	In Compliance	CS - CSO Complaint - Exterior - Complaint	2 dumpsters on the blvd just south of the garage
01/30/2019	19 007179	Inspected	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Fraser Morris Electric CO - MN ICE - TENANT REMODEL
01/15/2019	19 003884	Finaled	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - SILGAN BLDG 12 SUITE 236A AREA (T#9987) NEW PANEL, SUB PANEL & TRANSFORMER
01/15/2019	19 003882	Inspected	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - WATT SECOND SUITE 320 (T#9987) NEW PANEL & CIRCUITS
01/15/2019	19 003874	Finaled	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - BLDG 12 SUITE 236B OAK CARR (T#9986) NEW PANEL & CIRCUITS
01/15/2019	19 003865	Finaled	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - NMSS-12 SUITE 230A (T#9986) NEW SUB PANEL & CIRCUITS
01/15/2019	19 003864	Finaled	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - TERRANCE MANN FINISHES LOWER LEVEL WITH NEW SUB PANEL & CIRCUITS (T#9986)
01/15/2019	19 003863	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - TERRANCE MANN FINISHES LOWER LEVEL WITH NEW SUB PANEL & CIRCUITS
01/15/2019	19 003857	Finaled	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - NEW SERVICE PANEL AND SUB PANEL. ROOF TOP UNITS ON BLDG 12
01/15/2019	19 003751	Abandoned	E - Electrical Permit - Electrical - Commercial New	Contractor Retrofit Electric - SERVICE PANELS FOR NEW ROOF TOP UNITS ON BLDG 12
01/11/2019	19 003023	Finaled	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDING #8, NMSS INSTALL SPIRAL DUCTWORK AND SIX (6) SIDEWALL REGISTERS ON EXISTING 5 TON RTU
01/09/2019	19 002414	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - ROO PHOTOGRAPHY STUDIO -

01/08/2019	19 001896	Pending	RF - Referral - State Daycare	INSTALLATION OF DEMISING WALLS & DOORS, PLUMBING & MECHANICAL UNDER SEPARATE PERMITS Owner 755 N Prior Ave Llc/C/O Orton Development Inc - first floor suite 002A for 54 children.
01/03/2019	19 000944	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Repair/Alter	Contractor Clint Anderson Legacy Companies Inc - CAN CAN WONDERLAND INSTALL RTU-6,7,8,9, DUCTWORK, DIFFUSERS, GAS PIPING TO HVAC EQUIPMENT
01/03/2019	19 000939	Inspected	M - Mechanical Permit - Gas - Commercial Replace	Contractor Clint Anderson Legacy Companies Inc - CAN CAN WONDERLAND INSTALL RTU-6,7,8,9, DUCTWORK, DIFFUSERS, GAS PIPING TO HVAC EQUIPMENT CONDENSER LOCATED ON ROOF
12/28/2018	18 134635	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - SAUNDERS THERAPY ADD 19 SPRINKLER HEADS TO EXISTING FIRE PROTECTION SYSTEM FOR INTERIOR TENANT BUILD-OUT
12/21/2018	18 133382	Finald	EG - Fire Engineering - Special Extinguishing System - Existing Building - Alter Systems	Contractor Nardini Fire Equipment Co Inc - CAN CAN WONDERLAND, #004 INSTALLATION OF ANSUL R102 - 6 GALLON SYSTEM WITH COVERAGE OVER APPLIANCES ONSITE
12/21/2018	18 133367	Canceled	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Nardini Fire Equipment Co Inc - CAN CAN WONDERLAND, 755 JPRIOR AVE N #004 INSTALLATION OF ANSUL R102 - 6 GALLON SYSTEM WITH COVERAGE OVER APPLIANCES ONSITE This Folder was Cancelled during the Automatic Add phase.
12/21/2018	18 133477	In Compliance	CS - CSO Complaint - Permit - Complaint	Possible kitchen remodel work done without permit
12/13/2018	18 131136	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - TERRANCE MANN FINISHES STE 006B T#'S 9792,9793 & 9794
12/12/2018	18 130945	Finald	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDING 12 - PROVIDE AND INSTALL (20) DX ROOFTOP UNTS FOR FUTURE BUILDOUT OF BUILDING 12 (SEE ATTACHED PLANS)
12/12/2018	18 130944	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - (BUILDING 12 AKIDO) INSTALL SA DUCTWORK FROM EXISTING 6 TON ROOFTOP UNIT TO SERVE NEW TENANT SPACE (SEE ATTACHED DRAWING)
12/12/2018	18 130939	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDING 12 SAUNDERS THERAPY - INSTALL THE ABOVE FIXURES FOR TENANT BUILDOUT

				(SEE PLANS) (1) MISC FIXTURE JAN SINK
12/12/2018	18 130931	Inspected	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDING 12 - MINNESOTA ICE - INSTALL (3) SINKS IN NEW TENANT BUILDOUT
12/12/2018	18 130929	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - (BUILDING 12 - MINNESOTA ICE) INSTALL SA DUCTWORK FROM EXISTING 15 TON ROOFTOP UNIT (SEE ATTACHED)
12/12/2018	18 130917	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - (BUILDING 12 - SAUNDERS THERAPY) INSTALL SA DUCTWORK FROM EXISTING 5 & 6 TON ROOFTOP UNITS (SEE PLANS)
12/12/2018	18 130896	Inspected	M - Mechanical Permit - Gas - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - (BUILDING 12) EXTEND GAS PIPING FROM EXISTING MAIN ON ROOF TO (20) ROOFTOP UNITS
12/07/2018	18 129381	Finald	B - Building Permit - Commercial - Remodel	Contractor Rod Mussen - NMSS- INSTALLATION OF DEMISING WALLS, CEILING, AND DOORS PER PLANS. ELECTRICAL AND MECHANICAL UNDER SEPERATE PERMIT.
11/21/2018	18 125075	Inspected	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING (6) NEW CIRCUITS FOR PARKING RAMP GATES UPPER & LOWER RAMPS (T#9659)
11/21/2018	18 125067	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING NEW SEVICES WITH TRANFORMER FOR BUILDING #12 LOADING DOCK & HALLWAY (T#9659)
11/21/2018	18 125058	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING NEW SEVICES AND TRANSFORMERS IN SUITE 235E SAUNDERS THERAPY
11/21/2018	18 125036	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING TWO NEW SERVICES AND TRASFORMER IN SUITE 237 MN ICE (T#9658)
11/14/2018	18 122757	Finald	WA - SPRWS Plumbing Permit - Existing Building - Outside - Repair	Contractor Ted Olson Valley Rich Co Inc - 815 PRIOR AVE N - REPAIR 3" WATER LINE
11/12/2018	18 122075	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - NEW SERVICE PANEL WITH BREAKERS AND FIXTURES. AKIDIO ROOM SUIT 235B
11/09/2018	18 121763	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - (LOWER LEVEL) MODIFY EXISTING LAVATORY PIPING AND LOCATIONS TO FACILITATE INSTALLATION OF NEW FAMILY RESTROOM.
11/08/2018	18 121462	Finald	EG - Fire Engineering - Sprinkler / Standpipe	Contractor Frontier Fire Protection - Add 23 sprinkler heads for new freezers and

11/08/2018	18 121459	Finald	Permit - Existing Building - Alter Systems EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	overhead door for MN Ice tenant space per NFPA 13 2010 Contractor Frontier Fire Protection - Add two heads for changing rooms below mezzanine in Aikido tenant space.
11/01/2018	18 119332	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - In Suite 104-add 100amp service, 2 heat pump connections, lights and receptacles.
10/29/2018	18 117729	Pending	CL - Compliance Checks - Liquor Compliance Check	Licensee Flanneljax's - ECLIPS License# 20180002381
10/22/2018	18 115595	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - 2nd FLOOR WORK IN BATHROOMS, LOUNGE & EGRESS AREAS WITH NEW CIRCUITS, HEAT PUMP, EXIT 7 EMERGENCY LIGHTS & FIXTURES. TICKET#9252
10/19/2018	18 115340	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE - 529, INSTALLATION OF DEMISING WALLS, CEILING, AND DOORS. ELECTRICAL AND MECHANICAL UNDER SEPERATE PERMIT.
10/19/2018	18 115338	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE - 235E - SAUNDERS PT - INSTALLATION OF DEMISING WALLS, CEILING, AND DOORS. ELECTRICAL AND MECHANICAL UNDER SEPERATE PERMIT.
10/18/2018	18 081063	Active/Issued	XL - ECLIPS License - Liquor - Liquor On Sale - 100 seats or less	Licensee Flanneljax's - ECLIPS License# 20180002381
10/18/2018	18 081070	Active/Issued	XE - ECLIPS License - Entertainment - Entertainment (B)	Licensee Flanneljax's - ECLIPS License# 20180002381
10/13/2018	18 113226	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - ADD 31 HEADS FOR CLOUDS IN SELECT ROOMS OF THE COLLEGE POSSIBLE SPACE
10/08/2018	18 111326	Issued	EG - Fire Engineering - Alarm Permit - Existing Building - Alter Systems	Contractor Johnson Controls Security Solutions LLC - CAN CAN WONDERLAND - ADD 15 SMOKES, 15 SPEAKER-STROBES, 3 RELAYS FOR ENTERTAINMENT SPACE
10/08/2018	18 111312	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Johnson Controls Security Solutions LLC - CAN CAN WONDERLAND - ADD 15 SMOKES, 15 SPEAKER-STROBES, 3 RELAYS FOR ENTERTAINMENT SPACE
10/08/2018	18 111305	Issued	EG - Fire Engineering - Alarm Permit - Existing Building - Alter Systems	Contractor Johnson Controls Security Solutions LLC - ADD FIRE ALARM EQUIPMENT - ANNUNCIATOR, ANSUL MONITORING, DOOR RELEASE, VOICE-EVAC EQUIPMENT TO MAIN PANEL
10/08/2018	18 111303	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Johnson Controls Security Solutions LLC - ADD FIRE ALARM EQUIPMENT - ANNUNCIATOR, ANSUL MONITORING, DOOR RELEASE,

10/03/2018	18 109954	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Repair/Alter	VOICE-EVAC EQUIPMENT TO MAIN PANEL Contractor Clint Anderson Legacy Companies Inc - CAN CAN WONDERLAND - INSTALL MUA-1, PRV-1, OWNER PROVIDED KITCHEN HOOD, ILF-1, DISHWASHER HOOD, DUCTWORK, DIFFUSERS, GAS PIPING TO HVAC EQUIPMENT, MODIFICATIONS TO EXISTING DUCTWORK FROM RTU-3&5 TO ACCOMMODATE NEW MEZZANINE.
10/03/2018	18 109948	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Clint Anderson Legacy Companies Inc - CAN CAN WONDERLAND - INSTALL MUA-1, PRV-1, OWNER PROVIDED KITCHEN HOOD, ILF-1, DISHWASHER HOOD, DUCTWORK, DIFFUSERS, GAS PIPING TO HVAC EQUIPMENT, MODIFICATIONS TO EXISTING DUCTWORK FROM RTU-3&5 TO ACCOMMODATE NEW MEZZANINE.
10/03/2018	18 053391	Active/Issued	XW - ECLIPS License - Water/Health - Health/Sport Club	Licensee Fly Freak Yoga - ECLIPS License# 20180001314
10/02/2018	18 109514	Finald	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 235B - AIKIDO OF MINNESOTA - INSTALLATION OF DEMISING WALLS, OFFICE, AND DOORS.
10/02/2018	18 109510	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 237 - MINNESOTA ICE - INSTALLATION OF DEMISING WALLS, CONCRETE, AND DOORS.
09/24/2018	18 107219	Withdrawn	B - Building Permit - Commercial - Repair	Contractor Alyssa Olson Quality Trusted Commercial Construction & Roofing - DUPLICATE PERMIT - SEE PERMIT 18-106592 - WITHDRAWN RE-ROOF USING GENFLEX TPO AND EPDM MEMBRANE
09/21/2018	18 106592	Active/Issued	B - Building Permit - Commercial - Repair	Contractor Alyssa Olson Quality Trusted Commercial Construction & Roofing - Other-See Comments. RE-ROOF USING GENFLEX TPO & EPDM MEMBRANE
09/18/2018	18 105487	Under Review	SR - Site Plan Review - Parking Lot - Mixed Use	Applicant Rod Musson 755 N. Prior Ave., LLC - Parking site plan. Previous site plan #16-039002
09/17/2018	18 104733	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Midwest Fire Protection Incorporated - Drop 8 sprinkler heads under new mezzanine. Can Can space, next to the kitchen, in the lower level
09/12/2018	18 103241	Open	FA - Fire Alarm Malfunction	Responsible Party Rod Musson 755 Prior LLC - Attn: Property Manager
09/10/2018	18 102354	Active/Issued	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - "SENSORIUM" IS AN ARTS-BASED FUN HOUSE COMPRISED

				OF SEVERAL DIFFERENT ROOMS ALL CONTAINING DIFFERENT EXPERIENCES.
09/06/2018	18 101217	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building 1 - 2nd floor Common Hall. Add 2 and relocate 1 for new common hall walls.
08/30/2018	18 099673	Active/Issued	BS - Billboard / Sign - Signs - Commercial New	Contractor Connie Schad Schad-Tracy Signs Inc - FLANNELJAX'S - COPY TO READ: FLANNELJAX'S - EXTREME, SOCIAL, FUN! State Electrician: MJ Electric
08/22/2018	18 096934	Issued	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Strange Paradise-Bldg. 2-Basement. Add/relocate 14 heads for new walls in Strange Paradise space.
08/22/2018	18 096933	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Our Car-Bldg. 8 Suite 304D. Add 5 heads for new walls.
08/20/2018	18 096327	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Bruce Nelson Bruce Nelson Plbg & Htg Service Inc - Can Can Kitchen Remodel - RELOCATE EXISTING 3 CAMP SINK AND GREAS TRAP. ADD REMAING FIXURES.
08/17/2018	18 095608	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Can Can Wonderland Common Hallway-Add 3 heads for new common corridor wall.
08/14/2018	18 094673	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING (2) NEW DISSCONNECTS 30A 480V 3PH (T#9252) ROOFTOP UNIT - YOGA FLYING FREAK
08/14/2018	18 094669	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING NEW LIGHTS, OUTLETS & DATA (T#9252) COLLEGE POSSIBLE COLLEGE POINT C
08/14/2018	18 094664	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING (1) NEW PANEL 200A 3PH 120/208 WITH BREAKERS SUITE 202 (T#9252) COLLEGE POSSIBLE COLLEGE POINT C
08/14/2018	18 094657	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING (1) 200A 3PH 480V PANEL WITH BREAKERS STE 201 (T#9252) COLLEGE POSSIBLE HEAT PUMP PANEL
08/14/2018	18 094632	Inspected	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING NEW LIGHTS AND OUTLETS WITH DATA (T#9252) COLLEGE POSSIBLE D
08/14/2018	18 094624	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING (2) NEW 200A 3PH 120/208V PANELS WITH BREAKERS. SUITE 203 (T#9252) COLLEGE POSSIBLE CAFE D
08/14/2018	18 094590	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING (2) NEW 200A 3PH 120/208 PANELS WITH BREAKERS.(COLLEGE POSSIBLE CAFE D) SUITE 203 T#9252
08/14/2018	18 094484	Finald		Contractor Charles Howard Pulse Electric Inc. - CanCan

			E - Electrical Permit - Electrical - Commercial New	Wonderland-Renovation, add new mezzanine with offices.
08/14/2018	18 094482	Inspected	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - CanCan Wonderland-Relocate concessions, add tap cooler, relocate kitchen equipment.
08/14/2018	18 094477	Active/Issued	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - CanCan Woderland -Power/lighting for new arcade in hallway.
08/14/2018	18 094459	Inspected	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - Tenant Improvement for new CanCan Suite in 755 Building (The Lab) Addition of receptacles/lighting
08/03/2018	18 091003	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - COMMON HALL/BATH - INSTALLATION OF DEMISING WALLS & DOORS, PLUMBING, ELECTICAL, & MECHANICAL UNDER SEPARATE PERMITS
07/31/2018	18 089895	Inspected	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - NEW LIGHTS, OUTLETS & DATA (T#9252) COLLEGE POSSIBLE MN TEAM B
07/31/2018	18 089894	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - NEW 200 AMP SERVICE (t#9252) COLLEGE POSSIBLE SUITE 200
07/31/2018	18 089892	Inspected	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - ADDING NEW LIGHTS AND OUTLETS (T#9252) COLLEGE POSSIBLE NATIONAL TEAM A
07/31/2018	18 089891	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Adding 200A Disconnect And 112.5 KVA Transformer. (T#9252) College Possible Suite 201
07/30/2018	18 089109	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - ADD/RELOCATE 32 HEADS FOR NEW WALLS IN COLLEGE POSSIBLE SPACE
07/26/2018	18 087985	Finald	EG - Fire Engineering - Alarm Permit - Existing Building - Alter Systems	Contractor Tyco Integrated Security LLC - ADD DUCT SMOKE DETECTORS AS PER WARM AIR INPSECTOR.
07/26/2018	18 087983	Finald	E - Electrical Permit - Unit Table Only - Commercial Repair/Alter	Contractor Tyco Integrated Security LLC - ADD DUCT SMOKE DETECTORS AS PER WARM AIR INPSECTOR.
07/25/2018	18 087500	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - WASTE, VENT, CW & HW PIPING FOR FIXTURES LISTED PER PLANS
07/25/2018	18 087496	Inspected	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - PROVIDE AND INSTALL SA DUCTWORK & SDIEWALL REGISTERS FROM WATER SOURCE HEAT PUMPS. INSTALL 1 INLNE FAN FOR NEW TOILET ROOMS. SEE PLANS.
07/25/2018	18 087488	Finald		Contractor Lynn Bishop Nac Mechanical & Electrical Services -

07/19/2018	18 085553	Inspected	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter E - Electrical Permit - Electrical - Commercial New	HEAT PUMPS WILL BE INSTALLED ON 2ND FLOOR. SEE PLANS. Contractor Charles Howard Pulse Electric Inc. - Hour Car Tenant Improvement-New panel, wire heat pumps, lights and receptacles
07/13/2018	18 083634	Finald	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - EXTEND CWS, CWR AND CONDENSATE PIPING TO FOUR HEAT PUMPS
07/13/2018	18 083627	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - 3RD FLOOR - HOUR CAR
07/13/2018	18 083610	Active/Issued	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - 3RD FLOOR (HEAVY WOOD TIMBER BLDG) HOUR CAR - INSTALL DUCT WORK FROM 4 WATER SOURCE HEAT PUMPS. EXHAUST DUCTWORK FROM 1 CEILING MOUNTED FAN
07/12/2018	18 083021	Inspected	B - Building Permit - Commercial - Remodel	Contractor Robert Clapp Can Can Wonderland - SUITE 010 - EXPANSION PROJECT, 3 PARTY ROOMS, FULL KITCHEN, HVAC, ELECTRICAL & PLBG FOR CAN CAN WONDERLAND
07/11/2018	18 082542	Closed	RF - Referral - Citizen Complaint	Owner 755 N Prior Ave Llc/C/O Orton Development Inc - Blackstack Brewing was over capacity on (July 9, 2018). Every chair was filled, they brought in extra tables which were filled, there were people sitting on the floor and on the window sills, and there was a huge line outside yet they were still letting people in. You couldn't move inside and it took forever to get out due to everyone sitting on the floor and being packed in.
07/11/2018	18 082541	Transferred - Closed	CS - CSO Complaint - Certificate of Occupancy - Complaint	Blackstack Brewing was over capacity on (July 9, 2018). Every chair was filled, they brought in extra tables which were filled, there were people sitting on the floor and on the window sills, and there was a huge line outside yet they were still letting people in. You couldn't move inside and it took forever to get out due to everyone sitting on the floor and being packed in.
07/11/2018	18 082543	Resolved	CS - CSO Complaint - License - Complaint	Blackstack Brewing was over capacity on (July 9, 2018). Every chair was filled, they brought in extra tables which were filled, there were people sitting on the floor and on the window sills, and there was a huge line outside yet they were still letting people in. You couldn't move inside and it

07/09/2018	18 081454	Inspected	E - Electrical Permit - Electrical - Commercial New	took forever to get out due to everyone sitting on the floor and being packed in. Contractor Charles Howard Pulse Electric Inc. - Provide new 200Amp 480v feed, 150kva transformer and 3 200amp 208v panels for CanCan Wonderland Expansion. Provided circuits to new party rooms.
07/09/2018	18 081448	Abandoned	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - Provide new 200Amp 480v feed, 150kva transformer and 3 200amp 208v panels for CanCan Wonderland Expansion. Provided circuits to new party rooms, hallway power, hallway lighting.
07/09/2018	18 081437	Abandoned	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - Provide new 200Amp 480v feed, 150kva transformer and 3 200amp 208v panels for CanCan Wonderland Expansion
07/09/2018	18 081135	Closed	RF - Referral - Form 4	Owner 755 N Prior Ave Llc/C/O Orton Development Inc - Form 4: **See Comments**
07/09/2018	18 081134	In Compliance	CS - CSO Complaint - Certificate of Occupancy - Complaint	Form 4: **See Comments**
07/03/2018	18 079789	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Can-Can beer cooler. Install 3 dry pendent heads in new beer cooler.
06/25/2018	18 076881	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - CAN -CAN Lower Level Shop, Brick & Timber New Panel
06/25/2018	18 076878	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - CAN -CAN New Hallway, Restroom Area Lights, Outlets & Hand Driers
06/25/2018	18 076867	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Third Floor Hallway New Lights & Outlets
06/25/2018	18 076803	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - First Floor Suite #106 New Service Panel
06/25/2018	18 076798	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - First Floor Building #12 N. End Service Area New Panels & Transformer
06/25/2018	18 076791	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Second Floor N Service Area New Panels, Transformer & Disconnect
06/25/2018	18 076775	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Roo Photography Suite 301 New Service Panel
06/25/2018	18 076757	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Third N. Service Area. New Service Panels, Transformer and Disconnect
06/25/2018	18 076713	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Third Floor S. Service Area

06/25/2018	18 076700	Approved To Pay	E - Electrical Permit - Electrical - Commercial Repair/Alter	Adding new Panels, Transformer and Disconnect Contractor Retrofit Electric - Adding new Panels, Transformer and Disconnect
06/25/2018	18 076589	Finalized	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDING #12 - INSTALL ADA HEIGHT DRINKING FOUNTAIN & RELATED WASTE, VENT, & CW PIPING
06/22/2018	18 076169	Finalized	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - SUITE 301D - HOUR CAR - INSTALLATION OF DEMISING WALLS AND DOORS
06/22/2018	18 076166	Finalized	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - SUITE 200 - COLLEGE POSSIBLE - INSTALLATION OF DEMISING WALLS AND DOORS
06/19/2018	18 074467	Finalized	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Add 100 amp panel and 6 circuits for Clay Shop in basement.
06/12/2018	18 072338	Active/Issued	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - SUITE 0006C - SENSORIUM GALLERY - INSTALLATION OF DEMISING WALLS AND DOORS.
06/07/2018	18 070480	Inspected	B - Building Permit - Commercial - Remodel	Contractor Mike Sonnek / Richard Naughton / Loren Wille James Steele Constr Company - SUITE 010 - CAN CAN WONDERLAND - ADDITION OF A MEZZANINE LEVEL TO AN EXISTING INTERIOR WAREHOUSE SPACE.
06/06/2018	18 070300	Open	GT - General Activity Tracking - License	06/06/2018 Generated list of owners within 350' of Lumberjack City space for Ent. B lic. Emailed to KS for communication with her contacts. JWF
05/17/2018	18 063348	Finalized	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LOWER LEVEL CALLAHAN - INSTALL SINK AND WATER HEATER FOR TENANT SPACE.
05/17/2018	18 063345	Finalized	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LOWER LEVEL CERAMIC STUDIO - INSTALL SINK AND WATER HEATER FOR TENANT SPACE.
05/17/2018	18 063343	Finalized	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - 3RD FLR ROO PHOTOGRAPHY - INSTALL SINK AND WATER HEATER FOR TENANT SPACE.
05/17/2018	18 063340	Finalized	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL HWS & HWR PIPING TO FEED THE ABOVE HOT WATER UNIT HEATERS.
05/17/2018	18 063334	Active/Issued	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LOWER LEVEL CALLAHAN - INSTALL DUCTWORK FROM (1) WATER SOURCE HEAT PUMP.

05/17/2018	18 063332	Finald	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LOWER LEVEL CALLAHAN - INSTALL (1) 3-TON WATER SOURCE HEAT PUMP, CWS & CWR AND CD PIPING FOR LOWER LEVEL TENANT.
05/17/2018	18 063320	Active/Issued	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LOWER LEVEL CERAMIC STUDIO - INSTALL (1) HOT WATER PROPELLER UNIT HEATER.
05/17/2018	18 063316	Active/Issued	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - 3RD FLR - INSTALL DUCTWORK FROM (2) WATER SOURCE HEAT PUMPS.
05/17/2018	18 063315	Finald	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - 3RD FLR - INSTALL (2) WATER SOURCE HEAT PUMPS, CWS CWR & CD PIPING.
05/11/2018	18 061103	Finald	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - SUITE 1 - MITCH IBURG CERAMICS ----- INSTALLATION OF DEMISING WALLS AND DOORS. PLUMBING AND MECHANICAL UNDER SEPERATE PERMIT.
05/09/2018	18 060463	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building #2 - Add/relocate 12 heads at new conference rooms on 2nd/3rd floors.
05/08/2018	18 059869	Inspected	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL (1) 10 TON GAS FIRED RTU FOR NEW TENANT SPACE
05/08/2018	18 059861	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDING #12 - PROVIDE NG PIPING FROM EXISTING MAIN ON ROOF TO NEW RTU.
05/07/2018	18 059581	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building 12 - Main level. Add 6 heads to correct existing coverage deficiency on main level.
05/07/2018	18 059577	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Add/relocate 4 heads for new walls in basement suite 001 Mitch Iburg Ceramics.
04/30/2018	18 057354	Closed	GT - General Activity Tracking - Zoning	Master Sign Plan for the site.
04/23/2018	18 054915	Finald	EG - Fire Engineering - Alarm Permit - Existing Building - Alter Systems	Contractor Tyco Integrated Security LLC - ORTON DEVELOPMENT - ADDING DUCT SMOKE DETECTORS & DAMPER CONTROLS
04/23/2018	18 054913	Finald	E - Electrical Permit - Unit Table Only - Commercial Repair/Alter	Contractor Tyco Integrated Security LLC - ORTON DEVELOPMENT - ADDING DUCT SMOKE DETECTORS & DAMPER CONTROLS
04/20/2018	18 054585	Finald		

04/20/2018	18 054582	Finald	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - Add basement panel and 8 ckts
04/20/2018	18 054576	Approved To Pay	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - Add 100amp panel in basement and 5 ckts.
04/20/2018	18 054571	Approved To Pay	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - Add 100amp 208v panel in Basement with 5 ckts.
04/18/2018	18 053736	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building 12 - Suite 1220 - Freak Flying Yoga - Add 6 heads for new walls in Freak Flying Yoga suite #1220
04/17/2018	18 053277	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building 3 - 2nd floor - Replace (40) 3/4" end lines with new 1" pipe. Add 5 heads at bathrooms.
04/17/2018	18 053273	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building 8 - 2nd floor - Replace (18) 3/4" end lines with new 1" pipe.
04/17/2018	18 053269	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building 8 - 3rd floor. Add/relocate 6 heads for new walls in Suite 300 - Roo Photography.
04/17/2018	18 053025	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDING #12 - INSTALL NEW RESTROOM IN EXISTING WAREHOUSE. (SEE ATTACHED PLANS).
04/17/2018	18 053014	Active/Issued	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - BUILDING #12 - INSTALL EXHAUST SYSTEM FOR NEW RESTROOMS. (SEE ATTACHED PLAN). 04/17/2018 Received plan, forward to Gary R. ZL
04/16/2018	18 052781	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - New install of 100A Panel and circuits. T#8565
04/16/2018	18 052780	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - New install of 100A Panel and circuits. T#8565
04/10/2018	18 051106	Finald	B - Building Permit - Commercial - Remodel	Contractor Rod Mussen - SUITE 003B - CALLAHAN FRAMING COMPANY INSTALLATION OF DEMISING WALLS AND DOORS. PLUMBING AND MECHANICAL UNDER SEPARATE PERMIT.
04/10/2018	18 051102	Active/Issued	B - Building Permit - Commercial - Remodel	Contractor Rod Mussen - SUITE 1220 - FREAK FLYING YOGA STUDIO ---- INSTALLATION OF DEMISING WALLS AND DOORS. PLUMBING AND MECHANICAL UNDER SERARATE PERMIT.
04/04/2018	18 049199	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Grounding Service South Building, 1st, 2nd & 3rd floors

04/04/2018	18 049191	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Lower Level Electrical Room Adding (4) New Bus Plugs 200 Amp and (1) 400 Amp
04/04/2018	18 049181	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - New 200 Amp 600V Disconnect, 112.5 KVA Transformer and 400 Amp 120/208V Panel (3rd Floor N Electrical Room) T#8652
04/03/2018	18 048987	Finald	E - Electrical Permit - Electrical - Commercial New	Contractor Charles Howard Pulse Electric Inc. - New feeders and connections to (3) Make Up Air Units
04/02/2018	18 048873	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - New Service Panel, Transformer & Disconnects (3rd Floor South Electrical Room) T#8652
04/02/2018	18 048866	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - New 100AMP Panel (Lumber Jack City Suite 102) T#8652
03/29/2018	18 048078	Finald	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - SUITE 300- ROO PHOTOGRAPHY STUDIO - INSTALLATION OF DEMISING WALLS AND DOORS. PLBG & MECHANICAL UNDER SEPARATE PERMIT
03/27/2018	18 047188	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - 1st Floor-Add 200amp 480v disconnect, 112.5 kva transformer, 400amp 208v panel.
03/27/2018	18 047187	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - 1st Floor Kitchen/break room lights and receptacles. 8 new circuits.
03/27/2018	18 047185	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Adding 200amp 480v disconnect, 75kva transformer and 200amp 208v panel in basement.
03/27/2018	18 047172	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - In Basement-Add 200amp 480v disconnect switch, 75kva transformer and 225 amp 208v panel. Using 3 breakers in panel.
03/27/2018	18 047171	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - In Basement-Add 200amp 480v disconnect switch, 75kva transformer and 225 amp 208v panel. Using 3 breakers in panel.
03/22/2018	18 045518	Finald	EG - Fire Engineering - Alarm Permit - Existing Building - Alter Systems	Contractor Tyco Integrated Security LLC - ADD (6) SMOKE DETECTORS AND (3) RELAYS FOR ELEVATOR.
03/22/2018	18 045517	Finald	E - Electrical Permit - Unit Table Only - Commercial Repair/Alter	Contractor Tyco Integrated Security LLC - ADD (6) SMOKE DETECTORS AND (3) RELAYS FOR ELEVATOR.
03/13/2018	18 036996	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 010 - CAN CAN WONDERLAND - INSTALLATION OF DEMISING WALLS AND DOORS. PLUMBING, ELECTRICAL AND MECHANICAL UNDER SEPARATE PERMIT.

03/12/2018	18 036745	Active/Issued	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - MAKE UP AIR DUCTWORK FROM BASE BUILDING OA UNITS AND SA DUCTOWRK FROM FIVE (5) WATER SOURCE HEAT PUMPS, EXHAUST FAN AND DUCTWORK FOR TOILET ROOM EXHAUST AND INLINE FAN AND DUCTWORK FOR RESIDENTIAL HOOD (KITCHEN IS A WARMING KITCHEN)
03/12/2018	18 036742	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - COMMON SPACE PER PLANS
03/12/2018	18 036741	Finald	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL (5) OWNER FURNISHED WATER SOURCE HEAT PUMPS, OA DUCTWORK AND SA DUCTWORK FROM HEAT PUMPS
03/06/2018	18 034431	Canceled	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building #15. Replace 580 existing old sprinkler heads with new to match existing type per owner request. Canceled per Trevor Spoo
03/06/2018	18 034429	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building #12. Replace 660 existing old sprinkler heads with new to match existing type per owner request.
03/06/2018	18 034427	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building #3 - Third floor. Replace 29 pieces of 3/4" pipe with new 1" pipe per owner request.
03/06/2018	18 034425	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building #2 - Third floor. Replace 36 pieces of 3/4" pipe with new 1" pipe per owner request.
03/06/2018	18 034423	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building #2 - Second floor. Replace 36 pieces of 3/4" pipe with new 1" pipe per owner request.
03/06/2018	18 034422	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building #1 - Third floor. Replace 28 pieces of 3/4" pipe with new 1" pipe per owner request.
03/06/2018	18 034421	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building #1 - Second floor. Replace 20 pieces of 3/4" pipe with new 1" pipe per owner request.
03/06/2018	18 034420	Abandoned	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Building #1 - Second floor. Replace 20 pieces of 3/4" pipe with new 1" pipe per owner request.


02/15/2018	18 029288	Active/Issued	B - Building Permit - Commercial - Repair	Contractor Alyssa Olson Quality Trusted Commercial Construction & Roofing - Other-See Comments. RE-ROOF USING GENFLEX TPO MEMBRANE
02/14/2018	18 028928	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Add/relocate 2 heads on second floor for Lumber Jack tenant.
02/13/2018	18 028591	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 100 - COMMON MEETING ROOM -- INSTALLATION OF DEMISING WALLS AND DOORS.
02/12/2018	18 028432	Approved To Pay	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Lumbar Jack City Suite #102
02/12/2018	18 028431	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Lumbar Jack City Suite #102
02/12/2018	18 028425	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Can-Can X-LAB Suite #011 New Panel Lighting and Heater
02/12/2018	18 028417	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Can-Can Pinball Maint Room Suite #012 (New Panels & Lights)
02/12/2018	18 028413	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Grounding Service for Center BLDG for Inspection
02/12/2018	18 028388	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Change of Service for New Tennant (Center BLDG SW Corner)
02/07/2018	18 026823	Ready to Issue/Approved	BS - Billboard / Sign - Signs - Commercial New	Contractor Shari King Lawrence Sign & Nordquist Sign - COPY TO READ: LUMBERJACK CITY New sign to be installed on the north façade facing the parking lot.
01/16/2018	18 020015	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - REPLACE (35) 3/4" END LINE PIECES WITH NEW 1" PIPE, MODIFY (5) SPRINKLERS FOR BATHROOM FINISH.
01/09/2018	18 018180	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air Only - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LUMBERJACK CITY - INSTALL SA DUCTWORK FROM (6) WATER SOURCE HEAT PUMPS & EXTEND MUA DUCTWORK TO HEAT PUMPS
01/09/2018	18 018179	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - HEAVYWOOD TIMBER BLDG - UNIT HEATERS INSTALLED IN EXDISTING LOADING DOCK
01/09/2018	18 018178	Finald	M - Mechanical Permit - Steam or Hot Water - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LUMBERJACK CITY - HANG (6) HEAT PUMPS & EXTEND CWS & CWR PIPING FROM EXISTING VALVE & CAPPED MAINS
01/09/2018	18 018176	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LUMBERJACK CITY - EXTEND SANITARY WASTE AND VENT

				FROM NEW FIXTURES TO EXTEND STACKS
01/09/2018	18 018171	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air Only - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL DUCTWORK FROM (3) WATER SOURCE HEAT PUMPS & EXTEND MUA DUCTWORK INTO SPACE Sotera
01/09/2018	18 018170	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LOWER LEVEL STORAGE ROOM - INSTALL GS PIPING, VENTING AND UNIT HETER
01/09/2018	18 018166	Finald	M - Mechanical Permit - Steam or Hot Water - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - HEAT PUMPS ARE LOCATED ON FIRST FLOOR EAST, CWS & CWR PIPING WILL BE EXTENDED FROM EXISTING VALVE & CAPPED MAINS
01/09/2018	18 018165	Active/Issued	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - HEAVY WOOD TIMBER BLDG - EXTEND MUA DUCTWORK FROM EXISTING SHAFTS (PERMIT 17-204314), OUT TO FUTURE TENANT SPACES
12/19/2017	17 223303	Finald	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 102 - LUMBERJACK CITY - NSTALLATION OF DEMISING WALLS AND DOORS
12/18/2017	17 223077	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - CanCan Wonderland Pizza Oven
12/18/2017	17 223076	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Boiler Room lights and receptacles
12/18/2017	17 223074	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Wood Shop power and lighting
12/07/2017	17 219808	Canceled	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor South Side Electric Inc - 07/12/2018 Cancelled per contractor request. MN REMOVE ABANDONED CABLING. PROPERTY PROTECT CABLE IN FIRE PUMP ROOM. INSTALL PROPER CONNECTOR IN FIRE PUMP CONTROLLER. LABEL FACPS WITH CIRCUIT IDENTIFICATION.
12/04/2017	17 218639	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Brick & Timber Area (4) Staircases Lights, Outlets & Exits
12/04/2017	17 218632	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - 3rd Floor Egress Hall & House Panel
12/04/2017	17 218623	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - (4) New LED Exterior Lights Southside (Egress Walkway)
11/21/2017	17 216096	Finald	M - Mechanical Permit - Gas - Commercial New	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL ONE (1) TEMP ORARY HEATER AT 1ST, 2ND & 3RD FLOORS. TEMPAIR THP-750 750,000 (3).
11/14/2017		Finald		

	17 213640		B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 004 - PLUS ON BLOCK - INSTALLATION OF DEMISING WALLS & DOORS
10/30/2017	17 209585	Inspected	B - Building Permit - Commercial - Remodel	Contractor Matt Hornibrook Ryan Company Inc - BUILD RETAINING WALL TO ADD PARKING
10/25/2017	17 208378	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Install new electrical service for elevator
10/25/2017	17 208253	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - New bathrooms
10/25/2017	17 208239	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - New bathrooms
10/18/2017	17 206185	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - UNIT #101 - INSTALL SINK AND EXTEND WASTE, VENT AND CW PIPING TO NEW WET COLUMN.
10/18/2017	17 206184	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - UNIT #107 - INSTALL SINK AND EXTEND WASTE, VENT AND CW PIPING TO NEW WET COLUMNS.
10/18/2017	17 206181	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - UNIT #103 - INSTALL SINK W/WASTE, VENT AND CW PIPING EXTENDED TO NEW WET COLUMN.
10/17/2017	17 205817	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - upgrade voltage 1st floor egress add panel lights outlets exits
10/17/2017	17 205808	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - upgrade voltage add outlets exit lights
10/17/2017	17 205799	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - upgrade electrical add 100 A Panel
10/17/2017	17 205792	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - 1st floor stairs office add outlets lights
10/17/2017	17 205773	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - add hand dryers
10/17/2017	17 205760	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Goodwill 1st Floor Upgrade Voltage
10/17/2017	17 205726	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - 1st Floor Mechanical Upgrade voltage
10/17/2017	17 205725	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - 1st Floor Mechanical Upgrade voltage
10/12/2017	17 204316	Inspected	M - Mechanical Permit - Steam or Hot Water - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - HEAVY WOOD TIMBER BUILDING - PROVIDE & INSTALL INFRA- STRUCTURE FOR WATER SOURCE HEAT PUMP SYSTEM
10/12/2017	17 204314	Inspected		Contractor Lynn Bishop Nac Mechanical & Electrical Services -

10/12/2017	17 204310	Final	W - Warm Air, Ventilation & General Sheet - Warm Air Only - Commercial Replace	HEAVY WOOD TIMBER BUILDING - PROVIDE & INSTALL (3) GAS FIRED DX 100% OA MUA UNITS (SEE ATTACHED PLANS)
10/12/2017	17 204269	Final	M - Mechanical Permit - Gas - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - HEAVY WOOD TIMBER BUILDING - PROVIDE & INSTALL 2# NATURAL GAS PIPING TO THE ABOVE EQUIPMENT
10/12/2017	17 204269	Final	PG - Plumbing/Gasfitting/Inside Water Piping - Sewer/Disposal Only - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALLING 4 WET COLUMNS FOR FUTURE TENANT CONNECTION, EACH WET COLUMN TO HAVE 4" WASTE STACK, 3" VENT STACK, AND 2" CW RISER
10/11/2017	17 203923	Active/Issued	W - Warm Air, Ventilation & General Sheet - Warm Air Only - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL (1) DX FAN COIL UNIT, ROOF MOUNTED CONDENSING UNIT, REFRIGERATION PIPING, CONDENSATE PIPING, OA DUCTWORK & SA DUCTWORK FOR NEW 1ST FLOOR OFFICE (SEE ATTACHED PLANS)
10/11/2017	17 203912	Final	M - Mechanical Permit - Refrigeration - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL 2 TON CONDENSING UNIT & RELATED REFRIGERATION PIPING FOR NEW HORIZONTAL FAN COIL UNIT (SEE ATTACHED PLANS)
10/05/2017	17 202035	Ready to Issue/Approved	BS - Billboard / Sign - Signs - Commercial Replace	Contractor Shari King Lawrence Sign & Nordquist Sign - COPY TO READ: AMERICAN CAN BUILDING Existing freestanding sign along Prior Ave. in front of the water tower to be refaced.
10/02/2017	17 195081	Open	RE - Real Estate Assessments	Owner 755 N Prior Ave Llc
09/29/2017	17 143795	Active/Issued	B - Building Permit - Commercial - Express Repair	Contractor Alyssa Olson Quality Trusted Commercial Construction & Roofing - Reroof of a section of commercial building with GenFlex TPO
09/20/2017	17 081401	Final	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - Final Inspection For Suite 102 Sotera.
09/19/2017	17 080958	Final	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - RELOCATE 7 SPRINKLERS IN THE BASEMENT FOR COMMON BATHROOM RENOVATION. RELOCATE 5 ON THE 1ST FLOOR COMMON BATHROOM
09/14/2017	17 079794	Final	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 101 - SOTERA TSCHETTER INC - INSTALLATION OF DEMISING WALLS AND DOORS. PLBG & MECHANICAL UNDER SEPARATE PERMITS
09/06/2017	17 077197	Final	EV - Elevating Device - Freight - Commercial Modernization	Contractor All City Elevator Inc - AMERICAN CAN-

				MODERNIZATION, SEE COVER LETTER
08/30/2017	17 075276	Open	FA - Fire Alarm Malfunction	Responsible Party Rod Musson 755 Prior LLC - Attn: Property Manager
08/02/2017	17 065791	Approved To Pay	E - Electrical Permit - Electrical - Commercial New	Contractor Retrofit Electric - Install of New Panel & Breakers for new Tenant.
07/21/2017	17 062116	Finald	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 103 - AUNE FERNANDEZ LANDSCAPE ARCHITECTS - INSTALLATION OF DEMISING WALLS, KITCHENETTE, & DOORS
07/03/2017	17 056143	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air Only - Commercial Replace	Contractor Paul Schoenecker Faircon Service Company - REMOVE/ REPLACE FURNACE W/ NEW HIGH EFF - 92%
07/03/2017	17 056139	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Paul Schoenecker Faircon Service Company - REMOVE/ REPLACE 120,000 BTU FURNACE W/ NEW EQUIPMENT OF SAME SIZE.
07/03/2017	17 056131	Finald	M - Mechanical Permit - Refrigeration - Commercial Replace	Contractor Paul Schoenecker Faircon Service Company - INSTALL 5 TON AC FOR REPLACEMENT SPLIT SYSTEM
06/29/2017	17 055353	Approved To Pay	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric - NEW PANEL AND CIRCUITS FOR SUITE #111. ROUGH IN AND FINAL INSPECTIONS REQUIRED. *** (T#7222)***
06/20/2017	17 052120	Resolved	CS - CSO Complaint - Garbage Rubbish - Complaint	Dumpster full of rotting "HOPS"- foul horrid odor, leaking from dumpster, northern parking lot by railroad tracks
06/18/2017	17 051212	Finald	RW - PW Right of Way Permit - Excavation - Utility	Contractor Accounts Payable / Cc: D Lewis/ J Bauer Comcast Of Minnesota, Inc. - BORE 91' CNDT & CB FROM ES OF PRIOR S OF CHELTON TO WS OF PRIOR FOR SVC @ 755 PRIOR AVE CITY PLAN 17- 376 APPROVED- 06/06/17 COMCAST PROJ- JT- 24110B GSOC- 171652875 REQUESTED BY- NICK SARANTOS 651-775-1713
06/09/2017	17 048732	Active/Issued	XE - ECLIPS License - Entertainment - MAD - Game Machines	Licensee Lawrence Bieza Larry's Pin Stuff - ECLIPS License# 20170002255
06/07/2017	17 047387	Closed	RF - Referral - Citizen Complaint	Owner 755 N Prior Ave Llc
05/24/2017	17 042644	Finald	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 107 - 651 MEDIA, LLC -- INSTALL DEMISING WALLS AND DOORS
05/19/2017	17 041046	Active/Issued	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - SUITE 105 - WILLY'S WOOD RESTORATION -- INSTALLATION OF DEMISING WALLS, AND DOORS.
05/15/2017	17 038795	Pending	CL - Compliance Checks - Liquor Compliance Check	Licensee Scott Johnson Black Stack Brewing Inc - ECLIPS License# 20150004254
05/15/2017	17 038794	Pending	CL - Compliance Checks - Liquor Compliance Check	

				Licensee Scott Johnson Black Stack Brewing Inc - ECLIPS License# 20150004254
05/15/2017	17 038790	Pending	CL - Compliance Checks - Liquor Compliance Check	Licensee Scott Johnson Black Stack Brewing Inc - ECLIPS License# 20150004254
05/10/2017	17 037700	Withdrawn	BS - Billboard / Sign - Signs - Commercial New	Contractor Shari King Lawrence Sign & Nordquist Sign - COPY TO READ "AMERICAN CAN BUILDING" ** UPDATE ** Withdrawn due to inactivity. Reopened under 17-202035 (11/26/18, MG).
05/08/2017	17 036563	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - BLDG 3 AND 8 MAIN CORRIDOR - MODIFY (11) FIRE SPRINKLERS ON THE LOWER LEVEL AND FIRST FLOOR FOR A TOTAL OF 22 SPRINKLERS.
05/08/2017	17 036556	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Repair	Contractor Olsen Fire Protection Olsen Fire Protection Inc - BLDG 2 - (12) 3/4" END LINES TO BE REPLACED W/ NEW 1" PIPE
05/05/2017	17 036185	Active/Issued	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - REMODEL.
05/05/2017	17 036179	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - REMODEL. 07/25/2018: Reopened by Jim Kaufer
05/04/2017	17 035816	Open	CS - CSO Complaint - Permit - Complaint	Remodeling the building, smells of burnt materials, complainant is concerned about lead paint flying around, there are no tarps, need erosion control
05/03/2017	17 035135	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - REPLACE (4) 3/4" END LINES WITH NEW 1" PIPE, EXTEND (6) PENDENTS TO NEW CEILING
04/25/2017	17 032380	Resolved	CS - CSO Complaint - License - Complaint	SMELL: brewery makes the area smell like 'skunk' 05.03.2017 - building #15 emitting "burning smell" at 1:32pm on 05.03.2017; complainant refused to leave contact information and refused to be transferred to licensing
04/12/2017	17 028624	Finald	RW - PW Right of Way Permit - Excavation - Utility	Contractor Sue Blue / Steve Gorsuch Centurylink - BORE 1907' CNDT & CB WS OF PRIOR BET UNIVERSITY & CHELTON CITY PLAN 17-065 APPROVED- 04/08/17 C-LINK PROJ- N213960 -B2 GSOC- CALL BEFORE YOU DIG REQUESTED BY- JAKE UMBREIT 320-292-7950 
04/06/2017	17 026609	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor James Vinzant Vinzant Industries - install new circuit for a commercial dishwasher in suite 113.
04/06/2017	17 026600	Abandoned		Contractor James Vinzant Vinzant Industries - install new

			E - Electrical Permit - Electrical - Commercial Repair/Alter	40 amp circuit for a commercial dishwasher
03/31/2017	17 025039	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - IN THE LOWER LEVEL OF THE BUILDING #2 REPLACE 32 END 3/4" LINES WITH NEW 1" LINES
03/27/2017	17 023218	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - 1890 WOOD BLDG AREA. LOWER LEVEL AND 1ST FLOOR. REPLACE (120) 3/4" END LINE PICES W/ NEW 1". REMOVED "PLAN CHECK FEE" PER KATIE L. LV
03/24/2017	17 022659	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - INSTALLATION OF EGRESS HALLS AND RESTROOMS. SAC PAYMENT REQUIRED PER TENANT BUILD OUT
03/13/2017	15 189082	Active/Issued	XL - ECLIPS License - Liquor - Liquor On Sale - Sunday	Licensee Scott Johnson Black Stack Brewing Inc - ECLIPS License# 20150004254
03/13/2017	15 189083	Active/Issued	XE - ECLIPS License - Entertainment - Entertainment (A)	Licensee Scott Johnson Black Stack Brewing Inc - ECLIPS License# 20150004254
03/13/2017	15 189084	Active/Issued	XL - ECLIPS License - Liquor - Malt Off Sale (Brewery)	Licensee Scott Johnson Black Stack Brewing Inc - ECLIPS License# 20150004254
03/13/2017	15 189085	Active/Issued	XL - ECLIPS License - Liquor - Malt On Sale (Brewery Taproom)	Licensee Scott Johnson Black Stack Brewing Inc - ECLIPS License# 20150004254
03/10/2017	17 018719	Finald	WA - SPRWS Plumbing Permit - Existing Building - Inside - Add / Repair /Relocate/ Replace	Contractor Blue Water Plumbing & Heating Inc - INSTALL 2 NEW RPZ
03/09/2017	17 018327	Finald	RW - PW Right of Way Permit - Excavation - Utility	Contractor Sue Blue / Steve Gorsuch Centurylink - BORE 133' CNDT & CB ON WS OF PRIOR BET CHELTON & MINNEHAHA CITY PLAN 17-044 APPROVED- 02/09/17 C-LINK PROJ- N213960 -B GSOC- LOCATES REQUIRED TO DIG/POTHOLE REQUESTED BY- JAKE UMBREIT 320-292-7950
02/23/2017	17 013872	Closed	RF - Referral - Form 4	Owner 755 N Prior Ave Llc - UNDER RENOVATION NEED UPDATED KEYS FOR ALL BUSINESSES IN KEYBOX WHEN DONE.
02/23/2017	17 013871	In Compliance	CS - CSO Complaint - Certificate of Occupancy - Complaint	UNDER RENOVATION NEED UPDATED KEYS FOR ALL BUSINESSES IN KEYBOX WHEN DONE.
02/13/2017	17 010919	Finald	WA - SPRWS Plumbing Permit - Existing Building - Inside - Add / Repair /Relocate/ Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL NEW BALL VALVE
02/02/2017	17 008544	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - REMOVE (5) EXISTING WALL HUNG LAVATORIES AND INSTALL NEW W/ SENSOR

02/01/2017	17 008208	Ready to Issue/Approved	BS - Billboard / Sign - Commercial New	FAUCETS. Location of sinks- 1st floor existing bathrooms. Contractor Shari King Lawrence Sign & Nordquist Sign - AMERICAN CAN BUILDING - COPY TO READ: RED LOT, BLUE LOT, YELLOW LOT, PARKING, DO NOT ENTER
01/19/2017	17 004608	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
01/17/2017	17 003793	Closed	GT - General Activity Tracking - Zoning	Master Sign Plan
01/10/2017	17 002314	Inspected	EA - Elevator Annual Inspection - Passenger - Commercial	Management Company 755 N Prior Ave Llc
01/04/2017	17 000563	Pending	CL - Compliance Checks - Liquor Compliance Check	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20160003357
01/04/2017	17 000556	Pending	CL - Compliance Checks - Liquor Compliance Check	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20160003357
01/04/2017	17 000554	Pending	CL - Compliance Checks - Liquor Compliance Check	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20160003357
12/30/2016	16 111271	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - ADD EXIT SIGNS IN PARKING GARAGE
12/30/2016	16 084004	Active Pending Ren	XE - ECLIPS License - Entertainment - Entertainment (B)	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20160003357
12/30/2016	16 084008	Active Pending Ren	XE - ECLIPS License - Entertainment - Gambling Location	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20160003357
12/30/2016	16 084010	Active Pending Ren	XL - ECLIPS License - Liquor - Liquor On Sale - 2 AM Closing	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20160003357
12/30/2016	16 084015	Active Pending Ren	XL - ECLIPS License - Liquor - Liquor On Sale - Sunday	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20160003357
12/30/2016	16 084024	Active Pending Ren	XL - ECLIPS License - Liquor - Liquor On Sale - 291 or more Seats	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20160003357
12/28/2016	16 110553	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - PARKING AREA OUTSIDE OF CAN/CAN WONDERLAND - REPLACE 350 1/2" BRASS UPRIGHTS W/ NEW 1/2" 286* BRASS UPRIGHTS IN THE GARAGE AREA. ALSO ADD ONE NEW BRASS UP TO CAN CAN STAIR.
12/22/2016	16 109707	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Repair	Contractor Lynn Bishop Nac Mechanical & Electrical Services - REPLACE FIXTURES - LOWER LEVEL
12/22/2016	16 109637	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
12/22/2016	16 109572	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric

12/22/2016	16 109543	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - (NAC) NE (1) EXSITING SIMPLEX SEWAGE EJECTOR & REPLACE WITH NEW DUPLEX UNIT WITH NEW COVER, CONTROL PANEL, & ALARM (SEE ATTACHED SUBMITTAL)
12/22/2016	16 109542	Inspected	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL NEW EXHAUST FANS & RELATED DUCTWORK FOR EXISTING RESTROOMS, SEE ATTACHED PLANS FOR MORE INFORMATION
12/19/2016	16 108456	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - CAN / CAN EXITING - ADDITION TO EXISTING PERMIT 16-107023 FOR AN ADDITIONAL 200 HEADS
12/15/2016	16 107827	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc.
12/15/2016	16 107823	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Electrical wiring for indoor Mini-Golf Course
12/15/2016	16 107769	Closed	LC - DSI Env Health Complaint - Health-Safety-Environment	building 15 burning something that smells bad
12/15/2016	16 107560	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Wiring for Mini Golf Course peices
12/15/2016	16 107768	Resolved	CS - CSO Complaint - Pollution - Complaint	building 15 burning something that smells bad
12/14/2016	16 107023	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - CAN / CAN WONDERLAND - TENANT SPACE - REPLACE 170 BRASS UPRIGHTS STANDARD RESPONSE WITH NEW OF THE SAME TYPE ALL TO 286* NO PLAN PER KATIE
12/13/2016	16 106943	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Install data/comm wiring for cash registers, cameras, atm etc.
12/13/2016	16 106751	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - EXTEND 12 NEW QR 155 SEMI REC PENDENTS TO NEW CEILINGS. REPLACE 12 3/4" END LINES WITH NEW 1" UP RIGHT SPK STAY
12/12/2016	16 106417	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Install Structured cabling system for Can Can Wonderland Mini Golf course
12/12/2016	16 106415	Abandoned	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Charles Howard Pulse Electric Inc. - Install Structured cabling system for Can Can Wonderland Mini Golf course
12/12/2016	16 106199	Finald	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - ST PAUL TOOL LIBRARY - INSTALLATION OF DEMISING WALLS, HEAT & DOORS
12/09/2016		Finald		

	16 105816		PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Josh Deziel Blue Water Plumbing & Heating Inc - (Blue Water) TION TO PERMIT #15-169209.
12/02/2016	16 103822	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO - (Ryan) S & 1 WATER HEATER MISC FIXTURE IS PIPE INSIDE WALL REPAIR
11/29/2016	16 102732	Closed	RF - Referral - Citizen Complaint	Owner 755 N Prior Ave Llc - Bldg 15, something is burning and it smells through out the neighborhood.
11/29/2016	16 102731	Resolved	CS - CSO Complaint - Certificate of Occupancy - Complaint	Bldg 15, something is burning and it smells through out the neighborhood.
11/23/2016	16 101519	Closed	BW - Building Warning - Double/Penalty Fee	Owner 755 N Prior Ave Llc - Double fee plumbing performed without first obtaining the proper permits. Location first floor main level office area south building bathrooms by Ryan Plumbing. Witnessed by Plumbing Inspectors K.K. & R./J. on 11.22.16.
11/22/2016	16 101323	Canceled	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO - 2 SINKS & 1 WATER HEATER MISC FIXTURE IS PIPE INSIDE WALL REPAIR
11/02/2016	16 095047	Finald	BS - Billboard / Sign - Signs - Commercial New	Contractor Shelly Rees Signminds Inc - COPY TO READ: BLACKSTACK BREWING COMPANY
11/01/2016	16 094886	Closed	RF - Referral - Citizen Complaint	Owner 755 N Prior Ave Llc - Chronic problem smell from property burns throat and nose and smoke can be seen coming out of building.
11/01/2016	16 094885	Callback Pending	CS - CSO Complaint - Certificate of Occupancy - Complaint	Chronic problem smell from property burns throat and nose and smoke can be seen coming out of building.
10/31/2016	16 094318	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Repair/Alter	Contractor Paul Schoenecker Faircon Service Company - REMOVE 4000 CFM STEAM FAN COIL AND REPLACE RTU (2) 2,000 CFM HEFT FURNACE 10/31/2016 RECEIVED PLAN, FORWARD TO: Jerry M. ZL
10/31/2016	16 094311	Finald	M - Mechanical Permit - Refrigeration - Residential Replace	Contractor Paul Schoenecker Faircon Service Company - REMOVE AND INSTALL (2) 2000CFM PAYNE NIGH EFF. FURNACE WITH (2) 3.5 TON AIRCONDITIONER. INSTALL GAS FOR FURNACE. 10/31/2016 RECEIVED PLAN, FORWARD TO: Christi Dick. ZL
10/31/2016	16 094302	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Paul Schoenecker Faircon Service Company - REMOVE AND INSTALL (2) 2000CFM PAYNE NIGH EFF. FURNACE WITH (2) 3.5 TON AIRCONDITIONER. INSTALL GAS

10/21/2016	16 091652	Inspected	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	FOR FURNACE. 10/31/2016 RECEIVED PLAN, FORWARD TO: Christi Dick. ZL Contractor Erik Celms Hayes Mechanical - (Hayes) Can Can Updated 11.14.16 - 1 MISC FIXTURE - GREASE TRAP
10/20/2016	16 091314	Finaled	PG - Plumbing/Gasfitting/Inside Water Piping - Sewer/Disposal Only - Commercial Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO - (Ryan) (15' OF 4" WASTE LINE TO NEW SEWER SERVICE) (5' IN FROM NEW SEWER APPROX 30') (RE- ROUTE STORM 30' FOR RAMP INSTALLATION)
10/20/2016	16 091304	Finaled	M - Mechanical Permit - Gas - Commercial Repair/Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO - INSTALL GAS LINE TO DEDUCT METER AND PIPE UP TO PRODUCTION BOILER FOR BREWERY
10/07/2016	16 086904	Pending	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	
10/07/2016	16 086905	Finaled	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Mr CARY WENZEL Wenzel Plymouth Plumbing LLC - Sink located in True stone coffee
09/23/2016	16 082329	Finaled	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - SUITE #113 - TRUE STONE COFFE - EXTEND 3 SPRINKLERS FROM EXISTING PIPE ABOVE TO NEW CEILING
09/19/2016	16 080427	Finaled	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - MU THEATER PRODUCTIONS- INSTALLATION OF DEMISING WALLS, HVAC AND DOORS
09/07/2016	16 076814	Finaled	B - Building Permit - Commercial - Remodel	Contractor True Stone Coffee Roasters - INSIDE TASTING/ CUPPING ROOM
08/17/2016	16 069723	Closed	BW - Building Warning - Double/Penalty Fee	Owner 755 N Prior Ave Llc - Double Fee plumbing projects installed without first obtaining the proper plumbing permits, witnessed by Plumbing Inspector J.K. on site for a different project and per Senior Plumbing Inspector R. J. Letter sent to owner August 3rd, 2016, second letter sent to owner on 9/23/16. R.J.
07/28/2016	16 063348	Inspected	B - Building Permit - Commercial - Remodel	Contractor Midwest Superior Drywall - 105 LINEAL FEET OF INTERIOR DRYWALL USING METAL STUDS. INCLUDING AN OVERHEAD DOUBLE GLAZED GARGE DOOR, (2) MAN DOORS AND (2) WINDOWS.
07/08/2016	16 055207	Finaled	WA - SPRWS Plumbing Permit - Existing Building - Inside - Add / Repair /Relocate/ Replace	Contractor Gregory Ryan Ryan Plumbing & Heating CO - REPLACE 2ND VALVE AND CHECK VALVE

06/30/2016	16 053111	Finald	SS - PW Sewer Permit - Storm - Repair	Contractor Michael Ryan Ryan Plumbing & Heating Co Inc - Storm repair in parking lot
06/28/2016	16 052097	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Frontier Fire Protection - Can/Can - Add/relocate 22 heads for new walls and ceilings in Can Can Wonderland space.
06/24/2016	16 051297	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - LL PARKING GARAGE - 8 new floor drains and associated piping for parking garage drainage system. Sewage ejector
06/24/2016	16 051291	Finald	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL ONE (1) GAS FIRED MUA UNIT, TWO (2) EXHAUST FANS AND EIGHT (8) COMBINATION CO/NO2 SENSORS FOR A PARKING GARAGE VENTILATION SYSTEM
06/24/2016	16 051290	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL EXISTING OWNER FURNISHED MUA UNIT ON WESWT ROOF OF BLDG. GAS PIPING TO EXTEND FROM EXISTING MAIN IN LOWER LEVEL
06/24/2016	16 051287	Withdrawn	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Lynn Bishop Nac Mechanical & Electrical Services - 07/01/2016 SEE PERMIT 16-051297. AMW INSTALL 8 NEW FLOOR DRAINS AND ASSOCIATED PIPING FOR PARKING GARAGE DRAINAGE SYSTEM, MISC SEWAGE EJECTOR.
06/15/2016	16 047873	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO - Ryan REMODEL (2) BATHROOMS IN LOWER LEVEL - 7/7 MORE INFO REQUIRED IN THE FORM OF PLANS R.J.---6/22 - JK Plan needed 7/11/16 rec. plans -plan review complete. R.J.
06/13/2016	16 046580	Finald	EG - Fire Engineering - Alarm Permit - Existing Building - Alter Systems	Contractor Tyco Integrated Security LLC - CUSTOMER IS INSTALLING AN ELEVATOR. WE WILL INSTALL A SMOKE ON EACH FLOOR BY ELEVATOR OPENING (4). WE WILL ALSO INSTALL ELAYS, 1 SMOKE IS TO BE INSTALLED
06/13/2016	16 046575	Finald	E - Electrical Permit - Unit Table Only - Commercial Repair/Alter	Contractor Tyco Integrated Security LLC - CUSTOMER IS INSTALLING AN ELEVATOR. WE WILL INSTALL A SMOKE ON EACH FLOOR BY ELEVATOR OPENING (4). WE WILL ALSO INSTALL ELAYS, 1 SMOKE IS TO BE INSTALLED
06/08/2016	16 045166	Finald	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor James Vinzant Vinzant Industries - INSTALL

05/20/2016	16 039002	Approved	SR - Site Plan Review - Parking Lot - Industrial	POWER TO REPLACEMENT AC, ADD CIRCUITRY IN SUITE 113 Applicant ROD Musson Wycliff Bldg - Mill/Overlay existing parking lot, Widen Drive on Prior and parking garage in basement of building
05/17/2016	16 037534	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Repair	Contractor Olsen Fire Protection Olsen Fire Protection Inc - RUN NEW SENSING LINES FOR THE JOCKEY AND FIRE PUMPS
05/17/2016	16 037530	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - EXTEND 7 SPRINKLERS TO BELOW THE NEW MAIN ENTRANCE WOOD RAMP
05/17/2016	16 034342	Finald	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Patty Bourgeois Air Mechanical Inc - INSTALL CLASS "A" VENTING FROM COFFEE ROASTER WHICH IS BEING RELOCATED FROM ANOTHER LOCATION.
05/09/2016	16 034344	Finald	M - Mechanical Permit - Gas - Commercial Repair/Alter	Contractor Patty Bourgeois Air Mechanical Inc - Air Mech - RECONNECT COFFEE ROASTER GAS AFTER BEING RELOCATED FROM ANTOHER LOCATION. COFFEE ROASTER - 225,000 BTU
05/09/2016	16 034332	Finald	M - Mechanical Permit - Refrigeration - Commercial Repair/Alter	Contractor Patty Bourgeois Air Mechanical Inc - Air Mech - INSTALL CONDENSER AND COIL IN EXISTING AIR HANDLER
05/02/2016	16 032127	Finald	SS - PW Sewer Permit - Sanitary - Repair	Contractor Michael Ryan Ryan Plumbing & Heating Co Inc - Building in line and north of Pennock, repair to existing sanitary sewer. I researched the entire building for sewer records last week and determined this 15" sanitary running N-S near the building is a NROC, no record available. I suggest repair be made and lines be televised to determine if the line is even functional as it appears the 15" was bulkheaded in 1988.
04/22/2016	16 029668	Closed	GT - General Activity Tracking - Zoning	bee hive
04/22/2016	16 029658	Inspected	W - Warm Air, Ventilation & General Sheet - Warm Air Only - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - INSTALL ROOFTOP UNIT
04/22/2016	16 029655	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - NAC - INSTALL ROOFTOP UNIT
04/19/2016	16 028115	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor A E M Electric Services Corporation
04/07/2016	16 025211	Active Pending Ren	XA - ECLIPS License - Animals - Animal Permits (Exotic)	Licensee Kristie Allen Kristy Allen - ECLIPS License# 20160001031
03/29/2016	16 022331	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - ENTEND 8 DRY PENENT SPRINKLERS TO NEW COOLER
03/25/2016	16 021743	Closed	PG - Plumbing/Gasfitting/Inside	

			Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Timothy Hayes Lbp Mechanical Inc - Can Can Wonderland
03/15/2016	16 018532	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
03/15/2016	16 018491	Finald	EV - Elevating Device - Passenger - Commercial New	Contractor All City Elevator Inc - INSTALLING ONE NEW PASSENGER ELEVATOR IN AN ABANDON HOISTWAY
03/04/2016	16 015551	Finald	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Replace	Contractor Clint Anderson Legacy Companies Inc - INSTALL (5) RTU'S SPIRAL DUCTWORK AND DISTRIBUTION AND GAS PIPING TO UNITS. 03/04/2016 RECEIVED PLAN AND FORWARD TO: Jerry McKenzie. ZL
03/04/2016	16 015536	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Clint Anderson Legacy Companies Inc - Legacy Mech - INSTALL (5) RTU'S AND GAS PIPING TO UNITS.
03/03/2016	16 015184	Inspected	B - Building Permit - Commercial - Remodel	Contractor Rod Musson - INSTALLATION OF DEMISING WALLS, HALLS, RAMPS, STAIRS AND DOORS.
02/11/2016	16 009974	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
12/16/2015	15 186557	Inspected	B - Building Permit - Commercial - Remodel	Contractor Building Assets LLC - CAN CAN WONDERLAND - TENANT FINISH FOR MINI GOLF (INDOOR) SPACE
11/18/2015	15 180040	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
11/06/2015	15 177050	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Aaron Gunderson / Bob Grill Hunt Electric Corporation
10/13/2015	15 169209	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Josh Deziel Blue Water Plumbing & Heating Inc - Blue Water Brewery
10/12/2015	15 168815	Finald	E - Electrical Permit - Electrical - Commercial New	Contractor St Joseph Electric Inc
10/12/2015	15 168814	Closed	E - Electrical Permit - Electrical - Commercial New	Contractor St Joseph Electric Inc
10/12/2015	15 168811	Closed	E - Electrical Permit - Electrical - Commercial New	Contractor St Joseph Electric Inc
10/12/2015	15 168745	Closed	E - Electrical Permit - Electrical - Commercial New	Contractor St Joseph Electric Inc
10/07/2015	15 167307	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
09/30/2015	15 165137	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Navid Raboodan Mill City Heating & Cooling - Mill City - Brewery - Boiler
09/30/2015	15 165138	Finald	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter	Contractor Navid Raboodan Mill City Heating & Cooling - Mill City - Brewery - LP steam boiler
09/30/2015		Finald		

	15 165131		M - Mechanical Permit - Refrigeration - Commercial Repair/Alter	Contractor Navid Raboodan Mill City Heating & Cooling - Mill City - Brewery - Walk in cooler
09/16/2015	15 160433	Finald	W - Warm Air, Ventilation & General Sheet - Warm Air Only - Commercial Replace	Contractor Navid Raboodan Mill City Heating & Cooling
09/16/2015	15 160406	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Navid Raboodan Mill City Heating & Cooling - Mill City - Brewery - RTU and UH
08/25/2015	15 153717	Finald	B - Building Permit - Commercial - Remodel	Contractor Scott Johnson - SUITE 110 - BLACK STACK BREWERY
08/21/2015	15 152533	Finald	B - Building Permit - Commercial - Remodel	Contractor Building Assets LLC - CAN CAN WONDERLAND
07/09/2015	15 137795	Finald	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - SUITE 110
07/07/2015	15 136868	Inspected	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
06/23/2015	15 132503	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
06/20/2015	15 028344	Withdrawn	XE - ECLIPS License - Entertainment - Entertainment (B)	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20150001062
06/20/2015	15 028345	Withdrawn	XL - ECLIPS License - Liquor - Liquor On Sale - 100 seats or less	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20150001062
06/20/2015	15 028346	Withdrawn	XL - ECLIPS License - Liquor - Liquor On Sale - Sunday	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20150001062
06/20/2015	15 028348	Withdrawn	XL - ECLIPS License - Liquor - Liquor On Sale - 2 AM Closing	Licensee Rob Clapp, Unit 004 Can Can Wonderland - ECLIPS License# 20150001062
06/18/2015	15 130919	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
06/15/2015	15 129676	Finald	EG - Fire Engineering - Hazardous Materials - Tank Removal	Contractor Pocono Propane Tanks LLC - Remove 2 - 30,000 gallon and 1 - 18,000 gallon aboveground LP gas tanks
06/02/2015	15 125414	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Repair	Contractor Olsen Fire Protection Olsen Fire Protection Inc - Riser 2 leaking
05/21/2015	15 038261	Finald	B - Building Permit - Commercial - Repair	Contractor 755 N Prior Ave Llc - SUITE 114 - FOSTER WILLY SCULPTOR
05/21/2015	15 038260	Finald	B - Building Permit - Commercial - Repair	Contractor 755 N Prior Ave Llc - CORRIDOR EXTENSION #102 - BLACK STACK BREW TO SUBMIT FOR SEPARATE TENANT FINISH PERMIT-
05/21/2015	15 038257	Inspected	B - Building Permit - Commercial - Repair	Contractor 755 N Prior Ave Llc - SUITE 116 - LIVONIA WOODWORKS
05/21/2015	15 038051	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
05/21/2015	15 038041	Active/Issued	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
05/12/2015	15 034577	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
05/12/2015	15 034562	Finald		Contractor Retrofit Electric

			E - Electrical Permit - Electrical - Commercial Repair/Alter	
04/30/2015	15 031467	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - heater added to room needs a higher temp sprinkler
04/23/2015	15 029356	Inspected	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO
04/20/2015	15 028039	Inspected	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - SUITE 108 - ROSE OF LUCUS
04/20/2015	15 027950	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
04/14/2015	15 026426	Resolved	CS - CSO Complaint - Graffiti - Complaint	Graffiti.
04/14/2015	15 026427	Transferred - Closed	CS - CSO Complaint - Graffiti - Complaint	Graffiti.
04/08/2015	15 024779	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Gregory Ryan Ryan Plumbing & Heating CO - Ryan 10 UH's
04/08/2015	15 024776	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Replace	Contractor Gregory Ryan Ryan Plumbing & Heating CO
03/25/2015	15 020901	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
03/25/2015	15 020678	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - Change out 7 sprinklers to higher temperature sprinklers due to presence of heaters in suites.
03/18/2015	15 019106	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - Relocate approx 30 sprinklers, add approx 2-2" lines for new bathrooms, add approx 40 new sprinklers for new walls, add 6 new sprinklers to new sheetrock ceilings, rough in 6 drops for new coolers and freezer, plug approx 12 sprinklers inside new walls
03/17/2015	15 018705	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO - PUBLIC RESTROOMS
03/17/2015	15 018611	Finald	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc - SUITE 104 & 105
03/16/2015	15 017999	Closed	BW - Building Warning - Double/Penalty Fee	Owner 755 N Prior Ave Llc - Olsen Fire Protection did work in the soup kitchen without a permit Double Fee is required.BH
03/11/2015	15 017075	Inspected	B - Building Permit - Commercial - Remodel	Contractor Matt Hornibrook Ryan Company Inc - BLOOM -- PERMIT APPLICATION AND 2 SETS OF STRUCTURAL PLANS WITH BLOOM
03/02/2015	15 014556	Finald	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior LLC - SOLUPPA
03/02/2015		Finald		Contractor Retrofit Electric

	15 014464		E - Electrical Permit - Electrical - Commercial Repair/Alter	
03/02/2015	15 014221	Final	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
02/25/2015	15 013283	Final	M - Mechanical Permit - Refrigeration - Commercial Replace	Contractor Paul Schoenecker Faircon Service Company
02/20/2015	15 012071	Final	PG - Plumbing/Gasfitting/Inside Water Piping - Gasfitting Only - Commercial Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO - ADDITIONAL PERMIT TO PERMIT# 15-010955.
02/17/2015	15 010955	Final	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO
02/11/2015	15 009819	Final	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
02/11/2015	15 009810	Final	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
01/23/2015	15 005525	Final	EG - Fire Engineering - Alarm Permit - Existing Building - Alter Systems	Contractor Tyco Integrated Security LLC - Adding 5 smoke detectors for elevator.
01/23/2015	15 005523	Closed	E - Electrical Permit - Unit Table Only - Commercial Repair/Alter	Contractor Tyco Integrated Security LLC
01/23/2015	15 005522	Final	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Replace	Contractor Paul Schoenecker Faircon Service Company
01/23/2015	15 005516	Final	M - Mechanical Permit - Gas - Commercial Replace	Contractor Paul Schoenecker Faircon Service Company - Faircon MUA 03/25/2015: Re- opened by Christi Dick
01/22/2015	15 005120	Final	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior LLC - JIM BLOOM - CONTRACTOR WILL SUBMIT PLANS WITH MECHANICAL AND ELECTRICAL PLANS M&E PLAN SUBMITTED. 2- 17-15
01/20/2015	15 004135	Final	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
01/19/2015	15 004071	Final	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
12/31/2014	14 356807	Final	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Olsen Fire Protection Olsen Fire Protection Inc - Replace 48 pieces of 1" with 1 1/4 to provide adequate design for 16 foot storage class4 solid pile storage. .29 density per St. Paul without hose demand added into calculations
12/09/2014	14 352243	Final	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO
11/20/2014	14 348119	Final	M - Mechanical Permit - Gas - Commercial Replace	Contractor Lynn Bishop Nac Mechanical & Electrical Services - NAC 5 UH's

11/19/2014	14 347784	Finald	PG - Plumbing/Gasfitting/Inside Water Piping - Plumbing/Inside Water (All) - Commercial Alter	Contractor Gregory Ryan Ryan Plumbing & Heating CO
11/19/2014	14 347780	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Gregory Ryan Ryan Plumbing & Heating CO - Ryan- 10 UH's
10/28/2014	14 341418	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Retrofit Electric
10/13/2014	14 337184	Finald	B - Building Permit - Commercial - Remodel	Contractor 755 N Prior Ave Llc
10/06/2014	14 335370	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor All City Elevator Inc
10/03/2014	14 335044	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor All City Elevator Inc
09/26/2014	14 332259	Active/Issued	B - Building Permit - Commercial - Remodel	Contractor Alyssa Olson Quality Trusted Commercial Construction & Roofing
09/25/2014	14 332720	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Aaron Gunderson / Bob Grill Hunt Electric Corporation
08/08/2014	14 317552	Finald	WA - SPRWS Plumbing Permit - Existing Building - Inside - Add / Repair /Relocate/ Replace	Contractor Gregory Ryan Ryan Plumbing & Heating CO - Disconnect RPZ and remove account number 80753
07/24/2014	14 312651	Finald	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Retrofit Electric
07/03/2014	14 305275	Closed	PA - Parks Summary Abatement - Graffiti	Owner 755 N Prior Ave Llc - Tag on building (no other details provided) Issue ID 1161980, St Paul Connects
07/03/2014	14 305274	Transferred - Closed	CS - CSO Complaint - Graffiti - Complaint	Tag on building (no other details provided) Issue ID 1161980, St Paul Connects
10/23/2013	13 244479	Closed	PA - Parks Summary Abatement - Graffiti	Owner Silgan Containers Mfg Corp - Back side of building by rain tracks has lots of graffiti as well. Large NK tag. Lots of smaller illustrations on back of building as well. Issue ID: 741369 - 2 pictures and Map
10/23/2013	13 244478	Transferred - Closed	CS - CSO Complaint - Graffiti - Complaint	Back side of building by rain tracks has lots of graffiti as well. Large NK tag. Lots of smaller illustrations on back of building as well. Issue ID: 741369 - 2 pictures and Map SA - Issued See - 13 240491
10/22/2013	13 243799	Closed	RF - Referral - C of O	Owner 755 N Prior Ave Llc - MONITORING FILE FOR VACANT AREAS OF BUILDING Follow up on C of O folder approved with corrections.
10/22/2013	13 243798	Billing	CO - Certificate of Occupancy - Factory	Responsible Party Rod Musson 755 Prior LLC - Attn: Property Manager
10/21/2013	13 243335	Open	FA - Fire Alarm Malfunction	Responsible Party Fred Seebinger Silgan Containers Mfg.
10/10/2013	13 240491	Resolved	CS - CSO Complaint - Exterior - Complaint	Graffiti

09/19/2013	13 233977	Closed	PA - Parks Summary Abatement - Graffiti	Owner Silgan Containers Mfg Corp - Graffiti on sign attached to chain link fence.
09/19/2013	13 233976	Transferred - Closed	CS - CSO Complaint - Graffiti - Complaint	Graffiti on sign attached to chain link fence.
09/16/2013	13 232654	Resolved	CS - CSO Complaint - Exterior - Complaint	Graffiti - Issue ID: 745281 - Photo & Map in Document file.
09/13/2013	13 232006	Closed	PA - Parks Summary Abatement - Graffiti	Owner Silgan Containers Mfg Corp - Building is becoming a target for graffiti. It is in multiple locations. Issue ID: 741369 - Photo & Map.
09/13/2013	13 232005	Transferred - Closed	CS - CSO Complaint - Graffiti - Complaint	Building is becoming a target for graffiti. It is in multiple locations. Issue ID: 741369 - Photo & Map.
07/01/2013	13 204571	Closed	PA - Parks Summary Abatement - Graffiti	Owner Silgan Containers Mfg Corp - Graffiti on cement by sidewalk. Issue ID: 606906 - Picture and in Doc. File.
07/01/2013	13 204570	Transferred - Closed	CS - CSO Complaint - Graffiti - Complaint	Graffiti on cement by sidewalk. Issue ID: 606906 - Picture and in Doc. File.
02/22/2013	13 156455	Closed	GT - General Activity Tracking - Zoning - Compliance letters	
06/26/2012	12 074221	Closed	PA - Parks Summary Abatement - Graffiti	Owner Silgan Containers Mfg Corp - 755 Prior Ave N - on garage door
06/26/2012	12 074220	Transferred - Closed	CS - CSO Complaint - Graffiti - Complaint	755 Prior Ave N - on garage door
11/07/2011	11 297513	Resolved	CS - CSO Complaint - Tall Grass - Complaint	TG&W
10/17/2011	11 289261	Closed	PA - Parks Summary Abatement - Graffiti	Owner Silgan Containers Mfg Corp - on the east side of bldg
10/17/2011	11 289260	Transferred - Closed	CS - CSO Complaint - Graffiti - Complaint	on the east side of bldg
08/01/2011	11 257570	Resolved	CS - CSO Complaint - Tall Grass - Complaint	TGW-Blvd.
01/31/2011	11 010645	Open	FA - Fire Alarm Malfunction	Responsible Party Fred Seebinger Silgan Containers Mfg.
10/04/2010	10 905382	Resolved	CS - CSO Complaint - Tall Grass - Complaint	TGW
09/21/2010	10 900620	Finald	EG - Fire Engineering - Alarm Permit - Existing Building - Alter Systems	Contractor ADT Security Services Inc
09/21/2010	10 900619	Active/Issued	E - Electrical Permit - Unit Table Only - Commercial Repair/Alter	Contractor ADT Security Services Inc
08/25/2010	10 796370	Certified	CO - Certificate of Occupancy - Factory	Responsible Party Fred Seebinger Silgan Containers Mfg.
03/03/2010	10 115963	Open	FA - Fire Alarm Malfunction	Responsible Party Fred Seebinger Silgan Containers Mfg.
02/02/2010	10 017259	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	REPAIR VALVES ON ZONES 8 & 9
02/01/2010	10 016399	Closed	RF - Referral - Form 4	Owner Silgan Containers Mfg Corp - CREWS RESPONDED TO WATER FLOW FROM A SPRINKLER HEAD. RESPONDING COMPANIES SHUT OFF WATER TO 2 OF THE SPRINKLER RISERS TO BUILDING 12 ON THE EXTERIOR OF THE BUILDING, AND SILENCED ALARM, AND

04/10/2009	09 054467	Closed	RF - Referral - Citizen Complaint	RESPONDING KEYHOLDER TURNED OFF FIRE PUMP IN BASEMENT. WE ADVISED KEYHOLDER/ MAINTENANCE TO ENSURE REPAIR IS MADE PROMPTLY. Owner Silgan Containers Mfg Corp - Surface bolts on exit doors No emergency lighting in storage area
03/16/2009	09 041418	Closed	RF - Referral - Form 4	Owner Silgan Containers Mfg Corp - THIS WAS DRY SYSTEM THAT ACTIVATED ONE HEAD. THERE WAS NO FIRE. THE SYSTEM WAS SHUT DOWN. A ENGINEER FOR THE COMPANY ARRIVED ON SCENE AND STATED HE WOULD RESTORE THE SYSTEM. CREWS RESPONDED FOR A WATER FLOW ALARM AT 1755 TODAY (RUN #6652) AND FOUND A PIPE FLOWING, WITH WATER ON FIRST AND SECOND FLOORS OF A LARGE VACANT WAREHOUSE. DISPATCH ATTEMPTED TO CONTACT OWNER, AS THIS HAS HAPPENED SEVERAL TIMES IN THE PAST DAY. DISPATCH SPOKE WITH ALARM COMPANY, BUT OWNER COULD NOT BE REACHED AT SEVERAL NUMBERS. ALARM SYSTEM WAS SILENCED, ELECTRICAL TO SPRINKLER PUMP WAS SHUT OFF AND MAIN WATER WAS SHUT OFF IN THE BASEMENT.
02/10/2009	09 025034	Open	FA - Fire Alarm Malfunction	Responsible Party Fred Seebinger Silgan Containers Mfg.
12/15/2008	08 221844	Closed	RF - Referral - Form 4	Owner Silgan Containers Mfg Corp - UNAVAILABLE KEYS TO ACCESS THE BLDG. HAD TO BREAK A LOCKED BOX TO GARAGE OPENER ON THE OUTSIDE. BLDG IS UNSECURED. ALSO ALARM WOULD NOT RESET AND NEEDS ATTENTION. THANK YOU.
10/09/2008	08 174894	Inactive	E - Electrical Permit - Electrical - Commercial New	Contractor ADT Security Services Inc - 10/09/2009: Automatically closed by system due to no activity in one year.
10/01/2008	08 158904	Closed	RF - Referral - Form 4	Owner Silgan Containers Mfg Corp - Building access area was blocked with fencing and locks. Once inside the fenced area, still unable to gain access to interior due to additional locks on doors.
09/18/2008	08 152586	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	751 PRIOR AVE N - CONVERT THE WET PIPE SYSTEMS TO DRY PIPE SYSTEMS SO THE HEAT CAN BE TURNED OFF. 11 SYSTEMS TOTAL
05/06/2008	08 070550	Finald	RW - PW Right of Way Permit - Obstruction - Other Obstruction	Contractor David Smart Ironwood Companies - LOADING TRUCKS. USE OF ONE TRAFFIC

05/01/2008	08 067940	Finald	RW - PW Right of Way Permit - Obstruction - Other Obstruction	LANE. CONES AND SIGNS 9AM TO 3PM ONLY. Contractor David Smart Ironwood Companies - LOADING TRUCKS. USE OF ONE TRAFFIC LANE. CONES AND SIGNS 9AM TO 3PM ONLY.
04/09/2008	08 055814	Closed	RF - Referral - Form 4	Owner Silgan Containers Mfg Corp - NO ADDRESS NUMBERS AND SPRINKLER HEAD WAS KNOCKED OFF AND NEEDS TO BE REPLACED. o Address numbers and
10/16/2007	07 173415	Finald	EG - Fire Engineering - Hazardous Materials - Existing Building - Alter Systems	Contractor Bob Cheney Determan Brownie Inc. - ABANDON 4 TANKS. 1 - 5,000, 1 - 15,000, 2- 20,000 GALLON.
07/19/2007	07 118467	Closed	PA - Parks Summary Abatement - Graffiti	Owner Silgan Containers Mfg Corp - 755 Prior Ave N. (Water Tower ??? Not to sure what that means)
07/19/2007	07 118466	Closed	CS - CSO Complaint - Graffiti - Complaint	755 Prior Ave N. (Water Tower ??? Not to sure what that means)
03/01/2007	07 029948	Finald	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Silgan Containers Corp (Maint.) - 03/03/2008: Automatically closed by system due to no activity in one year.
12/14/2006	06 286584	History	CO - Certificate of Occupancy - Factory	Responsible Party Fred Seebinger Silgan Containers Mfg. - 282923330001
07/20/2006	06 112573	Finald - No Inspection	EG - Fire Engineering - Sprinkler / Standpipe Permit - Repair	SILGAN CONTAINER - REMOVE THE ROTATING ASSEMBLY OFF THE FIRE PUMP AND REBUILD.
02/17/2006	06 028290	Finald	SS - PW Sewer Permit - Sanitary - New	Contractor Al Webster Jr Webster Co Inc
02/17/2006	06 028291	Finald	SS - PW Sewer Permit - Storm - New	Contractor Al Webster Jr Webster Co Inc
02/17/2006	06 028292	Finald	SS - PW Sewer Permit - Storm - New	Contractor Al Webster Jr Webster Co Inc - American Can
02/16/2006	06 021266	Finald	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Silgan Containers Corp (Maint.) - 02/16/2007: Automatically closed by system due to no activity in one year.
05/26/2005	05 107986	Finald	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Silgan Containers Corp (Maint.)
02/22/2005	05 067835	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
10/07/2004	04 164585	Closed	RF - Referral - Citizen Complaint	Owner Silgan Containers Mfg Corp - SPRINKLER VIOLATION, PER REPORTS DATED 7/29/04.
09/27/2004	04 151117	Finald - No Inspection	EG - Fire Engineering - Sprinkler / Standpipe Permit - Repair	REPAIRE LINE IN NORTH WAREHOUSE
09/02/2004	04 141097	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
08/06/2004	04 129389	Finald	B - Building Permit - Commercial - Express Repair	Contractor Allweather Roof - Closed without final approval
03/19/2004	04 058026	Finald	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Silgan Containers Corp (Maint.)

03/04/2004	04 051743	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
03/01/2004	04 049471	Closed	RF - Referral - Form 4	Owner Silgan Containers Mfg Corp - COMPRESSOR FAILURE IN BASEMENT DRY SYSTEM. MAINTENANCE WORKING ON THE SYSTEM AFTER OUR FIRE RUN. UNABLE TO RESET ALARM.
01/20/2004	04 032857	History	CO - Certificate of Occupancy - Factory	Responsible Party George Forst Silgan Containers Corp. - 282923330001
01/20/2004	04 032858	Closed	RF - Referral - C of O	Owner Silgan Containers Mfg Corp - Follow up on C of O folder approved with corrections.
01/02/2004	04 017568	Finald - No Inspection	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	ADD/RELOCATE 9 HEADS
12/15/2003	03 413358	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
12/15/2003	03 413362	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
12/15/2003	03 413363	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
12/15/2003	03 413364	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
12/15/2003	03 413367	Finald	EV - Elevating Device - Freight - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
09/22/2003	03 355643	Finald	B - Building Permit - Single Family Dwelling - Express	Contractor All Weather Roof - Closed without final approval Repair
09/22/2003	03 355645	Finald	W - Warm Air, Ventilation & General Sheet - General Sheet Metal - Commercial Repair/Alter	Contractor All Weather Roof - Closed without final approval
07/01/2003	03 321938	Finald	B - Building Permit - Commercial - Express	Contractor Allweather Roof - Closed without final approval Repair
05/05/2003	03 294965	Finald	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Silgan Containers - Closed without final approval
03/10/2003	03 265104	Finald	E - Electrical Permit - Unit Table Only - Commercial Repair/Alter	Contractor Claude M Anderson Electric Co Inc
07/19/2002	02 140082	Finald - No Inspection	EG - Fire Engineering - Sprinkler / Standpipe Permit - Repair	REPLACE DRY PIPE VALVE AND FLOW SWITCH
05/06/2002	02 121220	Finald	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	REPLACE 2500 RECALLED HEADS.
03/15/2002	02 104777	Finald	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Silgan Containers
01/09/2002	02 067652	Finald	M - Mechanical Permit - Oil - Commercial Replace	Contractor Joel Carberry Pbbs Equipment Corp/Twin Cities Div
01/09/2002	02 067655	Finald	M - Mechanical Permit - Gas - Commercial Replace	Contractor Joel Carberry Pbbs Equipment Corp/Twin Cities Div
12/28/2001		Closed		

	01 243442		RF - Referral - Citizen Complaint	Owner Silgan Containers Mfg Corp - Olsen Sprinkler Report deficiencies
11/30/2001	01 238104	Finald	W - Warm Air, Ventilation & General Sheet - General Sheet Metal - Commercial Repair/Alter	Contractor Division V Sheet Metal Incorporated
08/30/2001	01 221414	Finald	B - Building Permit - Commercial - Express Repair	Contractor Allweather Roof - Closed without final approval
07/05/2001	01 213002	Finald - No Inspection	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	ONE SPRINKLER HEAD.
05/18/2001	01 204577	Active	PS - Pre-Fire Survey - Factory	Owner Silgan Containers/Manufacturing Corporation
03/27/2001	01 184131	Expired	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Silgan Containers
03/13/2001	01 023765	History	CO - Certificate of Occupancy - Factory	Responsible Party George Forst Silgan Containers Corp. - 282923330001
08/24/2000	00 140788	Finald	E - Electrical Permit - Saver Switch Only - Commercial Repair/Alter	Contractor Aaron Gunderson / Bob Grill Hunt Electric Corporation
02/14/2000	00 118866	Finald	E - Electrical Permit - Service & Circuits - Commercial Repair/Alter	Contractor Silgan Containers
02/11/2000	00 118649	Finald	EV - Elevating Device - Passenger - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
02/11/2000	00 118651	Finald	EV - Elevating Device - Passenger - Commercial Repair/Alter	Contractor Schindler Elevator Corporation
11/10/1999	99 115692	Withdrawn	B - Building Permit - Commercial - Express Repair	Contractor Centimar Corporation
11/10/1999	99 115693	Finald	B - Building Permit - Commercial - Express Repair	Contractor Centimar Corporation - Reshingle(w/TearOff).
07/29/1999	99 170452	Finald	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Silgan Containers Corp (Maint.)
12/09/1998	98 154933	Closed without Approval	M - Mechanical Permit - Gas - Commercial Repair/Alter	Contractor Jeffrey Zimmerman Alliant Mechanical - Closed without final approval
12/09/1998	98 154934	Closed without Approval	W - Warm Air, Ventilation & General Sheet - Warm Air & Ventilation - Commercial Repair/Alter	Contractor Jeffrey Zimmerman Alliant Mechanical - Closed without final approval
12/03/1998	98 154498	Closed without Approval	M - Mechanical Permit - Gas - Commercial Repair/Alter	Contractor Larry Bredahl Bredahl Plumbing Inc - Closed without final approval
09/28/1998	98 000434	Closed	FS - Fire Suppression Systems - Limited Use Limited Access - Commercial Repair/Alter	Contractor Silgan Cnt - Closed without final approval
08/27/1998	98 147229	Closed without Approval	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Collisys - Closed without final approval
06/25/1998	98 142103	Closed without Approval	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Silgan Containers Corp (Maint.) - Closed without final approval
06/10/1998				

	98 103856	Closed without Approval	PL - Plumbing & Gas Fitting (OLD) - Sprinkler Head- Stand Pipe-Fire Pump - Residential Repair/Alter	Contractor Larry Bredahl Bredahl Plumbing Inc - Closed without final approval
03/31/1998	98 135073	Closed without Approval	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Commonwealth Electric of Minnesota Inc - Closed without final approval
03/27/1998	98 024116	Closed without Approval	E - Electrical Permit - Electrical	Contractor Commonwealth Electric of Minnesota Inc - Closed without final approval
03/17/1998	98 134636	Closed without Approval	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Silgan Containers Corp (Maint.) - Closed without final approval
02/17/1998	98 000090	Closed	FS - Fire Suppression Systems - Other Fire Extinguishing Systems - Commercial Repair/Alter	Contractor Attn George Silgan Container - Closed without final approval
10/07/1997	97 128080	Finalized	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Silgan Containers
12/18/1996	96 097998	Closed without Approval	W - Warm Air, Ventilation & General Sheet - General Sheet Metal - Commercial Repair/Alter	Contractor Mr RORY MATTER Rayco Construction - Closed without final approval
10/04/1996	96 094594	Finalized	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Silgan Containers Corp (Maint.)
07/03/1995	95 075365	Finalized	E - Electrical Permit - Electrical - Commercial New	Contractor Commonwealth Electric of Minnesota Inc
06/07/1995	95 074276	Finalized	E - Electrical Permit - Electrical - Commercial New	Contractor Commonwealth Electric of Minnesota Inc
03/09/1995	95 116191	Finalized	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor American National Can
06/28/1994	94 104560	Finalized	W - Warm Air, Ventilation & General Sheet - General Sheet Metal - Commercial Repair/Alter	Contractor M. G. McGrath, Inc.
06/14/1994	94 103938	Closed without Approval	M - Mechanical Permit - Refrigeration - Commercial Install	Contractor Gordon Peters Master Mechanical, Inc. - Closed without final approval
03/22/1994	94 100583	Finalized	E - Electrical Permit - Electrical - Commercial New	Contractor American National Can (Maint.)
01/24/1994	94 098954	Finalized	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Silgan Containers Corp (Maint.)
01/12/1994	94 098676	Finalized	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Commonwealth Electric of Minnesota Inc
01/05/1994	94 098502	Closed without Approval	M - Mechanical Permit - Gas - Commercial Repair/Alter	Contractor Harold Bauer Combustion Heat & Power Inc - Closed without final approval
01/05/1994	94 098503	Closed without Approval	M - Mechanical Permit - Steam or Hot Water - Commercial Repair/Alter	Contractor Harold Bauer Combustion Heat & Power Inc - Closed without final approval
04/01/1991	91 045186	Canceled	XS - ECLIPS License - Miscellaneous - Cigarette/Tobacco	Licensee Rod Musson 755 N. Prior Ave., LLC - ECLIPS License# 0045186
06/06/1988	88 018925	Canceled	XC - ECLIPS License - Car/Taxi - Private Fuel Pump	Licensee American Can Company - ECLIPS License# 0018925
04/26/1968		History		

	68 002725		CO - Certificate of Occupancy - Factory	Responsible Party George Forst Silgan Containers Corp. - 282923330001
04/26/1968	68 012724	History	CO - Certificate of Occupancy - Factory	Responsible Party George Forst Silgan Containers Corp. - 282923330001
11/22/1954	54 001251	Red Tagged	EA - Elevator Annual Inspection - Freight - Commercial	Management Company Rod Musson
11/22/1954	54 001252	Inspected	EA - Elevator Annual Inspection - Freight - Commercial	Management Company Rod Musson
03/07/1951	51 001255	Red Tagged	EA - Elevator Annual Inspection - Freight - Commercial	Management Company Rod Musson
09/27/1926	26 001254	Red Tagged	EA - Elevator Annual Inspection - Freight - Commercial	Management Company Rod Musson
09/27/1924	24 001253	Red Tagged	EA - Elevator Annual Inspection - Freight - Commercial	Management Company Rod Musson
	24 001031	Closed	EV - Elevating Device - Freight - Commercial New	
	26 001032	Closed	EV - Elevating Device - Freight - Commercial New	
	51 001033	Closed	EV - Elevating Device - Freight - Commercial New	
	54 001029	Closed	EV - Elevating Device - Freight - Commercial New	
	54 001030	Closed	EV - Elevating Device - Freight - Commercial New	