



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

February 4, 2011

REVISED LETTER

Daniel Schmidt  
RC Public Health  
2875 White Bear Ave N, Ste. 350  
Maplewood MN 55109

VIA EMAIL: [daniel.schmidt@co.ramsey.mn.us](mailto:daniel.schmidt@co.ramsey.mn.us)

Re: Appeal for property at 746 Jessamine Avenue  
File ID: ALH 11-237

Dear Mr. Schmidt:

This is to confirm that on February 3, 2011, Marcia Moermond, Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 4-inch variance on the openable height of one double hung replacement egress bedroom window which measured at 20 inches high by 23 inches wide and granting a 2.9-inch variance on the openable height width of two casement replacement egress bedroom windows.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang  
Legislative Hearing Coordinator

c: Fire Supervisors (email)  
Pat Fish (email)  
Jim Bloom (email)  
Stephen Ubl (email)  
File

