



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

January 27, 2012

REVISED LETTER

Daniel Schmidt
RC Public Health
2875 White Bear Ave N, Ste. 350
Maplewood MN 55109

VIA EMAIL: daniel.schmidt@co.ramsey.mn.us

Re: Appeal for property at 1699 Case Avenue

Dear Mr. Schmidt:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, reviewed the above-referenced appeal and recommended that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 23.3 inches wide and grant a 4-inch variance on the openable height of one double hung replacement egress bedroom window measuring 20 inches high by 26.8 inches wide.

The City Council Public Hearing is scheduled for Wednesday, February 15, 2012 at 5:30 p.m. in Room 300 Council Chambers; however, you don't need to attend since the appeal has been granted.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Jim Bloom (email)
Stephen Ubl (email)