



RECEIVED

Scanned

APPLICATION FOR APPEAL

JUN 27 2011
CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 7-12-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

emitted

Address Being Appealed:

Number & Street: 1830 Mechanic Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Eva Smith

Address (if not Appellant's): 1830 Mechanic Ave

Phone Numbers: Business _____ Residence 952-457-1989 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 7 replacement windows that will not comply w/ egress policy window openings will be short in height by 6". Opening width and overall glazed area will be exceeded. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 24, 2011

APPEAL PROPERTY ADDRESS: 1830 MECHANIC AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 243514
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 7

Total Glazed Area Minimum 5 Square Feet	12.5 sq.ft.	Difference from Required Area	+7.5 sq.ft.
Width of Opening Minimum 20 Inches	36"	Difference from Required Opening	+16"
Height of Opening Minimum 24 Inches	18"	Difference from Required Opening	-6"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	OK

COMMENTS: Based on information provided above determination to be made by legislative hearing officer

Reviewed by: jps